

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1430011</b>	<b>TORRINGTON WATER COMPANY</b>	C	37,915	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			8,812	854		163	

Towns Served: HARWINTON, LITCHFIELD, NEW HARTFORD, TORRINGTON

## Monitoring Requirements

Water System Facility: **RAW SURFACE WATER BLENDED SAMPLE TAP (WSF ID: 00500)**

<b>Total Alkalinity (1927)</b>		<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
RAW SW BLENDED TAP (SP1)	2/1/25 - 2/28/25		Complete	
	3/1/25 - 3/31/25		Complete	
	4/1/25 - 4/30/25		Complete	
	5/1/25 - 5/31/25		Complete	
	6/1/25 - 6/30/25		Complete	
	7/1/25 - 7/31/25			
	8/1/25 - 8/31/25			
	9/1/25 - 9/30/25			
	10/1/25 - 10/31/25			
	11/1/25 - 11/30/25			
	12/1/25 - 12/31/25			

<b>Total Organic Carbon (2920)</b>		<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
RAW SW BLENDED TAP (SP1)	2/1/25 - 2/28/25		Complete	
	3/1/25 - 3/31/25		Complete	
	4/1/25 - 4/30/25		Complete	
	5/1/25 - 5/31/25		Complete	
	6/1/25 - 6/30/25		Complete	
	7/1/25 - 7/31/25			
	8/1/25 - 8/31/25			
	9/1/25 - 9/30/25			
	10/1/25 - 10/31/25			
	11/1/25 - 11/30/25			
	12/1/25 - 12/31/25			

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Chlorine Residual (1012)</b>		<b>40 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	2/1/25 - 2/28/25		Complete	
	3/1/25 - 3/31/25		Complete	
	4/1/25 - 4/30/25		Complete	
	5/1/25 - 5/31/25		Complete	
	6/1/25 - 6/30/25		Complete	

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	1/1/21 - 12/31/29			

<b>Total Coliform (3100)</b>		<b>40 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	2/1/25 - 2/28/25		Complete	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1430011</b>	<b>TORRINGTON WATER COMPANY</b>	C	37,915	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			8,812	854		163	

Towns Served: HARWINTON, LITCHFIELD, NEW HARTFORD, TORRINGTON

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Total Coliform (3100)</b>	<b>40 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		

<b>Disinfectant Byproducts - TTHM &amp; HAA5 (DBP)</b>	<b>6 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WEST PEARL RD TANK (05934)	1/1/25 - 3/31/25	2/1-2/28	Complete
	4/1/25 - 6/30/25	5/1-5/31	Complete
	7/1/25 - 9/30/25	8/1-8/31	
	10/1/25 - 12/31/25	11/1-11/30	
ARBOR RIDGE RD SS (05939)	1/1/25 - 3/31/25	2/1-2/28	Complete
	4/1/25 - 6/30/25	5/1-5/31	Complete
	7/1/25 - 9/30/25	8/1-8/31	
	10/1/25 - 12/31/25	11/1-11/30	
30 PECK RD SS (05940)	1/1/25 - 3/31/25	2/1-2/28	Complete
	4/1/25 - 6/30/25	5/1-5/31	Complete
	7/1/25 - 9/30/25	8/1-8/31	
	10/1/25 - 12/31/25	11/1-11/30	
CHARLOTTE HUNGERFORD HOSPITAL SS (05942)	1/1/25 - 3/31/25	2/1-2/28	Complete
	4/1/25 - 6/30/25	5/1-5/31	Complete
	7/1/25 - 9/30/25	8/1-8/31	
	10/1/25 - 12/31/25	11/1-11/30	
LAKERIDGE METER PIT - 17 GREENWOODS RD (05943)	1/1/25 - 3/31/25	2/1-2/28	Complete
	4/1/25 - 6/30/25	5/1-5/31	Complete
	7/1/25 - 9/30/25	8/1-8/31	
	10/1/25 - 12/31/25	11/1-11/30	
THOMPSONS METER HOUSE - 100 THOMPSON DR (05944)	1/1/25 - 3/31/25	2/1-2/28	Complete
	4/1/25 - 6/30/25	5/1-5/31	Complete
	7/1/25 - 9/30/25	8/1-8/31	
	10/1/25 - 12/31/25	11/1-11/30	

<b>Lead And Copper (PBCU)</b>	<b>30 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1430011	TORRINGTON WATER COMPANY	C	37,915	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			8,812	854		163	

Towns Served: HARWINTON, LITCHFIELD, NEW HARTFORD, TORRINGTON

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

**Lead And Copper (PBCU) 30 routine (RT) per three years**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/24 - 9/30/24	6/1-9/30	Complete

**Lead And Copper (PBCU) 60 routine (RT) per six months**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/25 - 6/30/25		Complete
	7/1/25 - 12/31/25		

**Physical Parameters (PPS) 40 routine (RT) per month**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		

**Water Quality Parameters Orthophosphate, Total Alkalinity, T (WQP8) 20 routine (RT) per six months**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/25 - 6/30/25		Complete
	7/1/25 - 12/31/25		

Water System Facility: TORRINGTON FILTRATION PLANT -ENTRY POINT (WSF ID: 00700)

**Net Gross Alpha (4000) 1 routine (RT) per three years**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT-WTPLANT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

**Uranium (4006) 1 routine (RT) per three years**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT-WTPLANT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

**Combined Radium-226/228 (4010) 1 routine (RT) per three years**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT-WTPLANT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

**Inorganic Chemicals (IOCS) 1 routine (RT) per year**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT-WTPLANT (3)	1/1/24 - 12/31/24		Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1430011	TORRINGTON WATER COMPANY	C	37,915	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			8,812	854		163	

Towns Served: HARWINTON, LITCHFIELD, NEW HARTFORD, TORRINGTON

### Monitoring Requirements

Water System Facility: **TORRINGTON FILTRATION PLANT -ENTRY POINT (WSF ID: 00700)**

<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WTPLANT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>	<b>2 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WTPLANT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WTPLANT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility: **ALLEN DAM RESERVOIR (WSF ID: 30090)**

<b>Total Coliform (3100)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ALLEN DAM RES INTAKE (SP1)	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
<b>Surface Water Inorganic Chemicals (RIOCI)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ALLEN DAM RES INTAKE (SP1)	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
<b>Surface Water Color and Turbidity (RPPS)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ALLEN DAM RES INTAKE (SP1)	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
<b>Surface Water Pesticides (RSOC)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ALLEN DAM RES INTAKE (SP1)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1430011</b>	<b>TORRINGTON WATER COMPANY</b>	C	37,915	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			8,812	854		163	

Towns Served: HARWINTON, LITCHFIELD, NEW HARTFORD, TORRINGTON

### Monitoring Requirements

Water System Facility: **ALLEN DAM RESERVOIR (WSF ID: 30090)**

<b>Surface Water Pesticides (RSOC)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 12/31/26		

Water System Facility: **REUBEN HART RES (WSF ID: 30091)**

<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
R HART RES INTAKE (SP1)	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

<b>Surface Water Inorganic Chemicals (RIOCI)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
R HART RES INTAKE (SP1)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

<b>Surface Water Color and Turbidity (RPPS)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
R HART RES INTAKE (SP1)	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

<b>Surface Water Pesticides (RSOC)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
R HART RES INTAKE (SP1)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Water System Facility: **TORRINGTON FILTRATION PLANT (WSF ID: 323)**

<b>Total Organic Carbon (2920)</b>		<b>1 routine (RT) per month</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - TORRINGTON TP (SP5)	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1430011</b>	<b>TORRINGTON WATER COMPANY</b>	C	37,915	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			8,812	854		163	

Towns Served: HARWINTON, LITCHFIELD, NEW HARTFORD, TORRINGTON

## Monitoring Requirements

Water System Facility: **TORRINGTON FILTRATION PLANT (WSF ID: 323)**

**Total Organic Carbon (2920)** **1 routine (RT) per month**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	12/1/25 - 12/31/25		

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **TORRINGTON FILTRATION PLANT -ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 12/1/2024	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
<b>Start Date:</b> 5/1/2023	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
<b>Start Date:</b> 5/1/2023	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	2/1/2025 - 2/28/2025	Y	
	3/1/2025 - 3/31/2025	Y	
	4/1/2025 - 4/30/2025	Y	
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025		
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.75 MG/L	2
<b>Start Date:</b> 12/1/2024	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT1430011</b>	<b>TORRINGTON WATER COMPANY</b>	C	37,915	P	SW

Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
	8,812	854			163	

Towns Served: HARWINTON, LITCHFIELD, NEW HARTFORD, TORRINGTON

**Water System Facility: TORRINGTON FILTRATION PLANT -ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.75 MG/L	2
<b>Start Date:</b> 12/1/2024		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring Compliance Status:</b>
		5/1/2025 - 5/31/2025	
		6/1/2025 - 6/30/2025	
Orthophosphate	<spaces> ( )	Maximum: 1.5 MG/L	2
<b>Start Date:</b> 12/1/2024		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring Compliance Status:</b>
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
		5/1/2025 - 5/31/2025	
		6/1/2025 - 6/30/2025	
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.2 PH	Daily
<b>Start Date:</b> 12/1/2024		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring Compliance Status:</b>
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
		5/1/2025 - 5/31/2025	
		6/1/2025 - 6/30/2025	
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 1.5 MG/L	2
<b>Start Date:</b> 12/1/2024		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring Compliance Status:</b>
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
		5/1/2025 - 5/31/2025	
		6/1/2025 - 6/30/2025	
Phosphate (as PO4)	<spaces> ( )	Maximum: 3.0 MG/L	2
<b>Start Date:</b> 12/1/2024		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring Compliance Status:</b>
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
		5/1/2025 - 5/31/2025	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1430011	TORRINGTON WATER COMPANY	C	37,915	P	SW

Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		8,812	854		163	

Towns Served: HARWINTON, LITCHFIELD, NEW HARTFORD, TORRINGTON

## Water System Facility: TORRINGTON FILTRATION PLANT -ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	<spaces> ( )	Maximum: 3.0 MG/L	2
<b>Start Date:</b> 12/1/2024		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring Compliance Status:</b>
		6/1/2025 - 6/30/2025	Compliance Status:

## Water System Facility: TORRINGTON FILTRATION PLANT (WSFID: 323)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 1/1/2004		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring Compliance Status:</b>
		2/1/2025 - 2/28/2025	Y
		3/1/2025 - 3/31/2025	Y
		4/1/2025 - 4/30/2025	Y
		5/1/2025 - 5/31/2025	Y
		6/1/2025 - 6/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
<b>Start Date:</b> 1/1/2004		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring Compliance Status:</b>
		2/1/2025 - 2/28/2025	Y
		3/1/2025 - 3/31/2025	Y
		4/1/2025 - 4/30/2025	Y
		5/1/2025 - 5/31/2025	Y
		6/1/2025 - 6/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
<b>Start Date:</b> 1/1/2004		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring Compliance Status:</b>
		2/1/2025 - 2/28/2025	Y
		3/1/2025 - 3/31/2025	Y
		4/1/2025 - 4/30/2025	Y
		5/1/2025 - 5/31/2025	Y
		6/1/2025 - 6/30/2025	

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
CROSS CONNECTION SURVEY REPORT	3/1/2025	
CERTIFY LEAD SL NOTIFICATION	7/1/2025	4/21/2025
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	9/28/2025	
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CERTIFY LEAD SL NOTIFICATION	7/1/2026	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1430011</b>	<b>TORRINGTON WATER COMPANY</b>	C	37,915	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			8,812	854		163	

Towns Served: HARWINTON, LITCHFIELD, NEW HARTFORD, TORRINGTON

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00500	RAW SURFACE WATER BLENDED SAMPLE TAP	SP1	RAW SW BLENDED TAP	A				
00600	DISTRIBUTION SYSTEM	05929	GREENBRIAR PS	A	Y			
		05930	SQUIRE HILL PS	A	Y			
		05931	WINTHROP ST PS	A	Y			
		05932	TORRINGFORD WEST ST	A	Y			
		05934	WEST PEARL RD TANK	A	Y			Y
		05935	SOAPSTONE HI TANK SS	A	Y			
		05936	HIGHLAND AVE TANK	A	Y			
		05937	LITCHFIELD ST TANK	A	Y			
		05939	ARBOR RIDGE RD SS	A	Y			Y
		05940	30 PECK RD SS	A	Y			Y
		05941	NORTH RD @ LENOR SS	A	Y			Y
		05942	CHARLOTTE HUNGERFORD	A	Y			Y
		05943	LAKERIDGE METER PIT	A	Y			Y
		05944	THOMPSONS METER HOUS	A	Y			Y
		05945	CUMB FARM - 291 SPIE	A	Y			
		05946	#610 PATCO MOBIL	A	Y			
		05947	BURRVILLE STP - HARR	A	Y			
		05948	RT 4 @ SMITH LN	A	Y			
		05949	LAKERIDGE OFFICE - E	A	Y			
		05950	SHELL - 1036 E MAIN	A	Y			
		4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		PB9163	144 ALLISON DR	I			1	
		PB9164	159 ALLISON DR	A			1	
		PB9165	182 ALLISON DR	A			1	
		PB9166	185 ALLISON DR	A			1	
		PB9167	370 ALLISON DR	A			1	
		PB9168	420 ALLISON DR	A			1	
		PB9169	432 ALLISON DR	A			1	
		PB9170	433 ALLISON DR	A			1	
		PB9171	446 ALLISON DR	A	Y		1	
		PB9172	12 CARRIAGE LN	A			1	
		PB9173	41 CARRIAGE LN	A			1	
		PB9174	104 CARRIAGE LN	A			1	
		PB9175	23 CASTLEWOOD LN	A			1	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1430011</b>	<b>TORRINGTON WATER COMPANY</b>	C	37,915	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			8,812	854		163	

Towns Served: HARWINTON, LITCHFIELD, NEW HARTFORD, TORRINGTON

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		PB9176	26 CASTLEWOOD LN	A		1		
		PB9177	32 CASTLEWOOD LN	A		1		
		PB9178	37 CASTLEWOOD LN	A		1		
		PB9179	57 CASTLEWOOD LN	A		1		
		PB9180	80 CASTLEWOOD LN	A		1		
		PB9181	89 CASTLEWOOD LN	A		1		
		PB9182	90 CASTLEWOOD LN	A		1		
		PB9183	250 CLEARVIEW AVE	A		1		
		PB9184	22 CONCORD RD	A		1		
		PB9185	100 CONCORD RD	A		1		
		PB9186	156 CONCORD RD	A		1		
		PB9187	168 CONCORD RD	A		1		
		PB9188	501 COUNTRY RD	A		1		
		PB9189	487 COUNTY RD	A		1		
		PB9190	219 COUNTY RD	A		1		
		PB9191	11 HEIGHTS DR	A		3		
		PB9192	10 KNOLLWOOD DR	A		1		
		PB9193	20 LAWRENCE LA	A		3		
		PB9194	30 LAWRENCE LA	A		1		
		PB9195	92 MIKELIN DR	A		1		
		PB9196	147 NORFOLK RD	A		1		
		PB9197	1389 NORFOLK RD	A		1		
		PB9198	18 RYAN TER	A		1		
		PB9199	30 RYAN TER	A		1		
		PB9200	40 RYAN TER	A		1		
		PB9201	220 SPRING ST	A		1		
		PB9202	279 SPRING ST	A		1		
		PB9203	20 TARA DR	A		1		
		PB9204	74 TARA DR	A		1		
		PB9205	102 TARA DR	A		1		
		PB9206	103 TARA DR	A		1		
		PB9207	595 TORRINGFORD ST	A		1		
		PB9208	603 TORRINGFORD ST	A		1		
		PB9209	615 TORRINGFORD ST	A		1		
		PB9210	741 TORRINGFORD ST	A		1		
		PB9211	24 VIEW ST	I		1		
		PB9212	32 VIEW ST	A		1		
		PB9277	361 CHESTNUT HILL RD	A		1		
		PB9278	132 COOLIDGE AVE	A		1		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1430011</b>	<b>TORRINGTON WATER COMPANY</b>	C	37,915	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			8,812	854		163	

Towns Served: HARWINTON, LITCHFIELD, NEW HARTFORD, TORRINGTON

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		PB9279	67 EGGLESTON ST	A		1		
		PB9280	42 FAIRLAWN DR	A		1		
		PB9281	377 HARWINTON AVE	A		1		
		PB9282	48 HASSIG RD	A		1		
		PB9283	51 JOHNSON ST	A		1		
		PB9284	84 JOHNSON ST	A		1		
		PB9285	96 JOHNSON ST	A		1		
		PB9286	104 JOHNSON ST	A		1		
		PB9287	116 JOHNSON ST	A		1		
		PB9288	32 JUNIPER CT	A		1		
		PB9289	49 LIBERTY LN	A		1		
		PB9290	504 LITCHFIELD ST	A		1		
		PB9291	132 MAPLEWOOD AVE	A		1		
		PB9292	153 MAPLEWOOD AVE	A		1		
		PB9293	90 NATHANIEL ST	A		1		
		PB9294	71 NORTHSIDE DR	A		1		
		PB9295	200 NORTHSIDE DR	A		1		
		PB9296	85 PUTNAM ST	A		1		
		PB9297	134 ROULIN ST	A		1		
		PB9298	144 ROULIN ST	A		1		
		PB9299	149 ROULIN ST	A		1		
		PB9300	156 ROULIN ST	A		1		
		PB9301	159 ROULIN ST	A		1		
		PB9302	168 ROULIN ST	A		1		
		PB9303	171 ROULIN ST	A		1		
		PB9304	178 ROULIN ST	A		1		
		PB9305	181 ROULIN ST	A		1		
		PB9306	188 ROULIN ST	A		1		
		PB9307	198 ROULIN ST	A		1		
		PB9308	199 ROULIN ST	A		1		
		PB9309	204 ROULIN ST	A		1		
		PB9310	207 ROULIN ST	A		1		
		PB9311	210 ROULIN ST	A		1		
		PB9312	126 SHIRLEY RD	A		1		
		PB9313	143 SHIRLEY RD	A		1		
		PB9314	164 SHIRLEY RD	A		1		
		PB9315	171 SHIRLEY RD	A		1		
		PB9316	178 SHIRLEY RD	A		1		
		PB9317	192 SHIRLEY RD	A		1		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1430011</b>	<b>TORRINGTON WATER COMPANY</b>	C	37,915	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			8,812	854		163	

Towns Served: HARWINTON, LITCHFIELD, NEW HARTFORD, TORRINGTON

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		PB9318	206 SHIRLEY RD	A		1		
		PB9319	110 W PEARL RD	A		1		
		PB9320	124 W PEARL RD	A		1		
		PB9321	202 W PEARL RD	A		1		
		PB9360	409 LITCHFIELD ST	I		1		
		PB9361	519 PROSPECT ST	I		1		
		PB9362	163 GROVE ST	I		1		
		PB9366	268 SPIELMAN HIGHWAY	I		2		
		TWC001	1970 NORFOLK RD	I	Y	3		
		TWC002	SQUIRE HILL P.S.	I	Y			
		TWC003	WINTHROP ST. P.S.	I	Y			
		TWC004	TORR. WEST ST P.S.	I	Y			
		TWC005	WEST PEARL TANK	I	Y			
		TWC006	HIGHFIELD DRIVE	I	Y			
		TWC007	CHAR HUNG. HOSP.	I	Y			Y
		TWC008	GREENBRIAR P.S.	I	Y			
		TWC009	59 ELMIRA	I		3		
		TWC010	33 SYCAMORE DR	I		1		
		TWC011	73 BRIGHTWOOD AVE	I		3		
		TWC012	111 SUNCREST CT	I		1		
		TWC013	1318 TORR. ST.	I		3		
		TWC015	517 PROSPECT ST	I		3		
		TWC016	20 LAWRENCE LANE	I		1		
		TWC017	55 BLINKOFF CT	I		3		
		TWC018	88 N CHAPEL ST	I		3		
		TWC019	193 LINCOLN AVE	I		3		
		TWC020	164 FUNSTON AVE	I		3		
		TWC021	126 MILL LANE	I		1		
		TWC022	91 VIEW ST	I		3		
		TWC023	57 DOROTHY DR	I		3		
		TWC024	130 SPRING ST	I		3		
		TWC025	76 ELMIRA	I		3		
		TWC026	107 DARTMOUTH ST	I		3		
		TWC027	109 COOLIDGE AVE	I		3		
		TWC028	149 BLAKE ST	I		N		
		TWC029	959 LITCHFIELD ST	I		3		
		TWC030	281 WYOMING AVE	I		N		
		TWC031	196 BRADFORD RD	I		3		
		TWC032	76 HIGH ST	I		3		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1430011</b>	<b>TORRINGTON WATER COMPANY</b>	C	37,915	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			8,812	854		163	

Towns Served: HARWINTON, LITCHFIELD, NEW HARTFORD, TORRINGTON

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		TWC033	129 MAPLEWOOD AVE	I		3		
		TWC034	7 WINSTED RD	I		3		
		TWC035	NORTH RD	I	Y	N		
		TWC037	25 COUNTRY CLUB RD	I		3		
		TWC038	NORTH RD, HRWTN	I	Y			Y
		TWC039	RTE 4 @ SMITH LANE	I	Y			
		TWC040	305 OAK AVE	I		N		
		TWC041	150 ALVORD PARK RD	I		3		
		TWC042	255 ROBERTS ST	I		N		
		TWC044	48 LIMESTONE DR.	I	Y			
		TWC045	197 RIVERSIDE AVE	I		3		
		TWC046	154 CENTRAL AVE	I		N		
		TWC047	220 HEIGHTS DRIVE	I		N		
		TWC048	523 TORR W. UNIT 34	I		1		
		TWC049	48 FUNSTON AVE	I		3		
		TWC050	59 COUNTY LINE RD	I		N		
		TWC051	185 SPRING ST	I		3		
		TWC052	490 LITCHFIELD ST	I		1		
		TWC053	117 LIMESTONE DR	I		3		
		TWC054	727 TORR ST	I		3		
		TWC055	11 MILICI DRIVE	I		N		
		TWC056	116 DAWES AVE	I		3		
		TWC057	302 VILLAGE DRIVE	I	Y	3		
		TWC058	77 DARTMOUTH STREET	I	Y	N		
		TWC059	ARBOR RIDGE	I				Y
		TWC060	30 PECK ROAD	I				Y
		TWC061	BURRVILLE STP	I	Y			
		TWC062	LAKERIDGE OFFICE	I	Y			
		TWC063	137 WINSTED RD	I		3		
		TWC064	1229 WINSTED RD 118	I		1		
		TWC065	1229 WINSTED RD 32	I		1		
		TWC066	1229 WINSTED RD 30	I		1		
		TWC067	1295 WINSTED RD 209	I		1		
		TWC068	1229 WINSTED RD 47	I		1		
		TWC069	212 WINSTED RD	I		N		
		TWC070	1229 WINSTED RD 10	I		1		
		TWC071	1275 WINSTED RD 536	I		1		
		TWC072	1275 WINSTED RD 426	I		1		
		TWC073	1275 WINSTED RD 206	I		1		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1430011</b>	<b>TORRINGTON WATER COMPANY</b>	C	37,915	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			8,812	854		163	

Towns Served: HARWINTON, LITCHFIELD, NEW HARTFORD, TORRINGTON

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		TWC074	1275 WINSTED RD 422	I		1		
		TWC075	1275 WINTSED RD 639	I		1		
		TWC076	#610 PATCO MOBIL	I	Y			
		TWC078	BURRVILLE PACKAGE ST	I	Y			
		TWC079	1036 EAST MAIN ST	I	Y	N		
		TWC080	LAKERIDGE METER PIT,	I	Y			Y
		TWC081	CUMBERLAND FARMS	I	Y			
		TWC082	100 THOMPSON DR	I				Y
		TWC083	963 TORRINGFORD EAST	I	Y	3		
		TWC084	182 ALLISON DR	I		1		
		TWC085	370 ALLISON DR	I		1		
		TWC086	389 ALLISON DR	I		1		
		TWC087	177 LISLE ST #4	I		1		
		TWC088	100 CONCORD ST	I		1		
		TWC089	92 MIKELIN DR	I		1		
		TWC090	109 MILL LANE	I		1		
		TWC091	59 TRACY AVE	I		3		
		TWC092	22 CONCORD RD	I		1		
		TWC093	30 LAWRENCE LA	I		1		
		TWC094	11 HEIGHTS DR	I		1		
		TWC095	156 CONCORD RD	I		1		
		TWC096	57 EVANS ST.	I		1		
		TWC097	59 ELMWOOD TERR.	I		1		
		TWC098	157 MIGEON AVE	I		1		
		TWC099	95 HOLLY PL.	I		1		
		TWC100	61 BUTLER ST.	I		1		
		TWC101	17 CLARK ST.	I		1		
		TWC102	421 PROSPECT ST.	I		1		
		TWC103	359 PARK AVE	I		1		
		TWC104	38 EAGLE ST.	I		1		
		TWC105	52 CHESTNUT AVE	I		1		
		TWC106	40 HILL ST.	I		1		
		TWC107	212 WINDSTED RD	I		1		
		TWC108	140 SOUTH MAIN ST.	I		1		
		TWC109	53 GOSHEN ST.	I		1		
		TWC110	44 NEW LITCH ST.	I		1		
		TWC111	84 NEW LITCH ST.	I		1		
		TWC112	49 BROOK ST.	I		1		
		TWC113	39 GEORGE ST.	I		1		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1430011</b>	<b>TORRINGTON WATER COMPANY</b>	C	37,915	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			8,812	854		163	

Towns Served: HARWINTON, LITCHFIELD, NEW HARTFORD, TORRINGTON

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		TWC114	52 CHESTNUT AVE	I		1		
		TWC115	130 WORKMAN	I		2		
		TWC116	143-145 BEECHWOOD	I		2		
		TWC117	181-185 CALHOUN ST	I		2		
		TWC118	330 MIGEON AVE	I		2		
		TWC119	583-585 PROSPECT ST.	I		2		
		TWC120	18 PEARL ST.	I		2		
		TWC121	165 BERRY ST.	I		2		
		TWC122	8-10 PULASKI ST.	I		2		
		TWC123	37-41 NORWOOD ST	I		2		
		TWC124	135-137 WALL ST.	I		2		
		TWC125	102 BROOKSIDE AVE	I		2		
		TWC126	82 BROOKSIDE AVE	I		2		
		TWC127	55-57 CHESTNUT AVE	I		2		
		TWC128	186-188 WASHINGTON A	I		2		
		TWC129	210 ALLISON AVENUE	I		1		
		TWC130	500 BURL TRPK	I	Y	N		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	TORRINGTON FILTRATION PLANT -ENTRY POINT	3	ENTRY POINT-WTPLANT	A				
2247	REUBEN HART RESERVOIR	1	RESERVOIR	A				
2248	ALLEN DAM RESERVOIR	1	RESERVOIR	A				
2249	NORTH POND	1	RESERVOIR	A				
2250	WHIST POND	1	RESERVOIR	A				
2253	NICKEL MINE BROOK DIVERSION	1	RESERVOIR	A				
30090	ALLEN DAM RESERVOIR	SP1	ALLEN DAM RES INTAKE	A				
30091	REUBEN HART RES	SP1	R HART RES INTAKE	A				
323	TORRINGTON FILTRATION PLANT	SP5	EP - TORRINGTON TP	A				
45367	WEST TORRINGTON TANK							
45369	LITCHFIELD STREET TANK							
45371	TORRINGFORD WEST STREET TANK							
45373	WEST PEARL ROAD TANK							
45375	HIGHLAND AVENUE TANK							
45377	SOAPSTONE HILL TANK							
49315	GREENBRIAR TANK							
49317	SQUIRE HILL TANK 1							
49319	SQUIRE HILL TANK 2							

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1430011</b>	<b>TORRINGTON WATER COMPANY</b>	C	37,915	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			8,812	854		163	
Towns Served: HARWINTON, LITCHFIELD, NEW HARTFORD, TORRINGTON							

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
49321	WINTHROP ST PUMP STATION							
49323	TORRINGFORD WEST ST PUMP STATION							
49327	GREENBRIAR PUMP STATION							
49329	SQUIRE HILL PUMP STATION							
54546	WESTSIDE HIGH PUMP STATION							
62779	BOOSTER CHLORINATION STATION (NORTH RD)							

## Certified Operator Information

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

**Facility Classification:** CLASS 2 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
MEYERS, JAMES	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2027

**Water System Facility: TORRINGTON FILTRATION PLANT (WSF ID: 323)**

**Facility Classification:** CLASS 3 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
ROMA, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2026
PASSECK, PETER	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2027
RYLANDER, STEVEN M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2027
COLANGELO JR., JOSEPH M	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2028

**Water System Facility: BOOSTER CHLORINATION STATION (NORTH RD) (WSF ID: 62779)**

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
ROMA, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2026

## Contact Information

Name			Organization			Job Title		
<b>Mr. Robert J. Ulrich</b>			Aquarion Water Company of Ct			Vp-Supply & Utility		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
505 Huntington St.						Shelton	CT	06484
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
203-926-4320		203-929-5297		203-395-3205	rulrich@aquarionwater.com			
Contact Role(s): <b>Administrative Contact, Legal Contact</b>								

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1430011</b>	<b>TORRINGTON WATER COMPANY</b>	<b>C</b>	<b>37,915</b>	<b>P</b>	<b>SW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		8,812	854			163	

Towns Served: HARWINTON, LITCHFIELD, NEW HARTFORD, TORRINGTON

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

***End of schedule***