

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090011	BETHEL WATER DEPT	C	9,507	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			3,300				

Towns Served: BETHEL, DANBURY

Monitoring Requirements

Water System Facility: RAW SURFACE WATER ENTRY POINT - CHESTNUT (WSF ID: 00500)

Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RAW EP - CHESTNUT (1)	1/1/25 - 3/31/25		Out of Service
	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Surface Water Inorganic Chemicals (RIOC)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RAW EP - CHESTNUT (1)	1/1/24 - 12/31/24		Out of Service
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Surface Water Color and Turbidity (RPPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RAW EP - CHESTNUT (1)	1/1/25 - 3/31/25		Out of Service
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Surface Water Pesticides (RSOC)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RAW EP - CHESTNUT (1)	1/1/24 - 12/31/24		Out of Service
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Water System Facility: RAW SURFACE WATER ENTRY POINT - EUREKA (WSF ID: 00501)

Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RAW EP - EUREKA (1)	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Surface Water Inorganic Chemicals (RIOC)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RAW EP - EUREKA (1)	1/1/24 - 12/31/24		Out of Service
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Surface Water Color and Turbidity (RPPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RAW EP - EUREKA (1)	1/1/25 - 3/31/25		
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090011	BETHEL WATER DEPT	C	9,507	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			3,300				

Towns Served: BETHEL, DANBURY

Monitoring Requirements

Water System Facility: RAW SURFACE WATER ENTRY POINT - EUREKA (WSF ID: 00501)

Surface Water Pesticides (RSOC)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RAW EP - EUREKA (1)	1/1/24 - 12/31/24		Out of Service
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Chlorine Residual (1012)	10 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete

Asbestos (1094)	2 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/21 - 12/31/29		

Total Coliform (3100)	10 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		

Disinfectant Byproducts - TTHM & HAA5 (DBP)	2 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SPRING HILL P.S (SWS09)	1/1/25 - 3/31/25	3/1-3/31	Complete
	4/1/25 - 6/30/25	6/1-6/30	Complete
	7/1/25 - 9/30/25	9/1-9/30	
	10/1/25 - 12/31/25	12/1-12/31	
24 DODGINGTOWN RD (SWS10)	1/1/25 - 3/31/25	3/1-3/31	Complete
	4/1/25 - 6/30/25	6/1-6/30	Complete
	7/1/25 - 9/30/25	9/1-9/30	
	10/1/25 - 12/31/25	12/1-12/31	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090011	BETHEL WATER DEPT	C	9,507	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			3,300				

Towns Served: BETHEL, DANBURY

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Lead And Copper (PBCU)		20 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/24	6/1-9/30	Complete
	1/1/25 - 12/31/25	6/1-9/30	
	1/1/26 - 12/31/26	6/1-9/30	

Physical Parameters (PPS)		10 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		

Water System Facility: ENTRY POINT 1 - CHESTNUT RIDGE (WSF ID: 00700)

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHESTNUT RIDGE (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHESTNUT RIDGE (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHESTNUT RIDGE (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Inorganic Chemicals (IOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHESTNUT RIDGE (3)	1/1/24 - 12/31/24		Out of Service
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHESTNUT RIDGE (3)	1/1/24 - 12/31/24		Out of Service
	1/1/25 - 12/31/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090011	BETHEL WATER DEPT	C	9,507	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			3,300				

Towns Served: BETHEL, DANBURY

Monitoring Requirements

Water System Facility: ENTRY POINT 1 - CHESTNUT RIDGE (WSF ID: 00700)

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 12/31/26		
Pesticides, Herbicides and PCBs-Phase II (SOC2)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHESTNUT RIDGE (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
Pesticides, Herbicides and PCBs-Phase V (SOC5)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHESTNUT RIDGE (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHESTNUT RIDGE (3)	1/1/24 - 12/31/24		Out of Service
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Water System Facility: ENTRY POINT 2 - EUREKA (WSF ID: 00701)

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EUREKA (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EUREKA (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EUREKA (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EUREKA (3)	1/1/24 - 12/31/24		Out of Service
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EUREKA (3)	1/1/24 - 12/31/24		Out of Service
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090011	BETHEL WATER DEPT	C	9,507	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			3,300				

Towns Served: BETHEL, DANBURY

Monitoring Requirements

Water System Facility: ENTRY POINT 2 - EUREKA (WSF ID: 00701)

Pesticides, Herbicides and PCBs-Phase II (SOC2)		2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - EUREKA (3)	1/1/24 - 12/31/26			
	1/1/27 - 12/31/29			
Pesticides, Herbicides and PCBs-Phase V (SOC5)		2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - EUREKA (3)	1/1/24 - 12/31/26			
	1/1/27 - 12/31/29			
Organic Chemicals (VOCS)		1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - EUREKA (3)	1/1/24 - 12/31/24		Out of Service	
	1/1/25 - 12/31/25			
	1/1/26 - 12/31/26			

Water System Facility: ENTRY POINT - MAPLE AVE WELLS (WSF ID: 00702)

Inorganic Chemicals (IOCS)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - MAPLE AVE WELLS (3)	1/1/25 - 12/31/27		Complete	
Nitrate And Nitrite (NOX)		1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - MAPLE AVE WELLS (3)	1/1/24 - 12/31/24			
	1/1/25 - 12/31/25		Complete	
	1/1/26 - 12/31/26			
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - MAPLE AVE WELLS (3)	1/1/25 - 12/31/27			
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - MAPLE AVE WELLS (3)	1/1/23 - 12/31/25			
	1/1/26 - 12/31/28			
Organic Chemicals (VOCS)		1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - MAPLE AVE WELLS (3)	1/1/24 - 12/31/24		Complete	
	1/1/25 - 12/31/25			
	1/1/26 - 12/31/26			

Water System Facility: EUREKA FILTER PLANT (WSF ID: 10)

Total Organic Carbon (2920)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
COMBINED FILTER EFFLUENT - EUREKA (5)	2/1/25 - 2/28/25		Out of Service	
	3/1/25 - 3/31/25		Out of Service	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090011	BETHEL WATER DEPT	C	9,507	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			3,300				

Towns Served: BETHEL, DANBURY

Monitoring Requirements

Water System Facility: **EUREKA FILTER PLANT (WSF ID: 10)**

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	4/1/25 - 4/30/25		Out of Service
	5/1/25 - 5/31/25		Out of Service
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		

Water System Facility: **CHESTNUT RIDGE RESERVOIR (WSF ID: 2001)**

Total Alkalinity (1927)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CHESTNUT RIDGE RES (1)	2/1/25 - 2/28/25		Out of Service
	3/1/25 - 3/31/25		Out of Service
	4/1/25 - 4/30/25		Out of Service
	5/1/25 - 5/31/25		Out of Service
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CHESTNUT RIDGE RES (1)	2/1/25 - 2/28/25		Out of Service
	3/1/25 - 3/31/25		Out of Service
	4/1/25 - 4/30/25		Out of Service
	5/1/25 - 5/31/25		Out of Service
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		

Water System Facility: **EUREKA LAKE (WSF ID: 2003)**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090011	BETHEL WATER DEPT	C	9,507	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			3,300				

Towns Served: BETHEL, DANBURY

Monitoring Requirements

Water System Facility: **EUREKA LAKE (WSF ID: 2003)**

Total Alkalinity (1927)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EUREKA LAKE (1)	2/1/25 - 2/28/25		Out of Service
	3/1/25 - 3/31/25		Out of Service
	4/1/25 - 4/30/25		Out of Service
	5/1/25 - 5/31/25		Out of Service
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		

Total Organic Carbon (2920)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EUREKA LAKE (1)	2/1/25 - 2/28/25		Out of Service
	3/1/25 - 3/31/25		Out of Service
	4/1/25 - 4/30/25		Out of Service
	5/1/25 - 5/31/25		Out of Service
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		

Water System Facility: **MAPLE AVE WELL 1A (WSF ID: 60721)**

E. Coli (3014)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
MAPLE AVE - WELL 1A (2)	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: **MAPLE AVE WELL 2A (WSF ID: 60723)**

E. Coli (3014)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
MAPLE AVE - WELL 2A (2)	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090011	BETHEL WATER DEPT	C	9,507	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			3,300				

Towns Served: BETHEL, DANBURY

Monitoring Requirements

Water System Facility: **MAPLE AVE WELL 2A (WSF ID: 60723)**

E. Coli (3014)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	10/1/25 - 12/31/25		

Water System Facility: **CHESTNUT RIDGE FILTER PLANT (WSF ID: 9)**

Total Organic Carbon (2920)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
COMBINED FILTER EFFLUENT- CHESTNUT RIDGE (5)	2/1/25 - 2/28/25		Out of Service
	3/1/25 - 3/31/25		Out of Service
	4/1/25 - 4/30/25		Out of Service
	5/1/25 - 5/31/25		Out of Service
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT 1 - CHESTNUT RIDGE (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily
Start Date: 9/1/2003	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 9/1/2003	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090011	BETHEL WATER DEPT	C	9,507	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			3,300				

Towns Served: BETHEL, DANBURY

Water System Facility: **ENTRY POINT 2 - EUREKA (WSFID: 00701)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily
Start Date: 9/1/2003		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
		5/1/2025 - 5/31/2025	
		6/1/2025 - 6/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 9/1/2003		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
		5/1/2025 - 5/31/2025	
		6/1/2025 - 6/30/2025	

Water System Facility: **ENTRY POINT - MAPLE AVE WELLS (WSFID: 00702)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 7/1/2017		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
		5/1/2025 - 5/31/2025	
		6/1/2025 - 6/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 7/1/2017		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
		5/1/2025 - 5/31/2025	
		6/1/2025 - 6/30/2025	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090011	BETHEL WATER DEPT	C	9,507	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			3,300				

Towns Served: BETHEL, DANBURY

Water System Facility: **EUREKA FILTER PLANT (WSFID: 10)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 9/1/2003		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Compliance Status:
	Offline	2/1/2025 - 2/28/2025	n/a
	Offline	3/1/2025 - 3/31/2025	n/a
	Offline	4/1/2025 - 4/30/2025	n/a
	Offline	5/1/2025 - 5/31/2025	n/a
		6/1/2025 - 6/30/2025	Y

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 1/1/2005		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Compliance Status:
	Offline	2/1/2025 - 2/28/2025	n/a
	Offline	3/1/2025 - 3/31/2025	n/a
	Offline	4/1/2025 - 4/30/2025	n/a
	Offline	5/1/2025 - 5/31/2025	n/a
		6/1/2025 - 6/30/2025	Y

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 1/1/2005		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Compliance Status:
	Offline	2/1/2025 - 2/28/2025	n/a
	Offline	3/1/2025 - 3/31/2025	n/a
	Offline	4/1/2025 - 4/30/2025	n/a
	Offline	5/1/2025 - 5/31/2025	n/a
		6/1/2025 - 6/30/2025	Y

Water System Facility: **CHESTNUT RIDGE FILTER PLANT (WSFID: 9)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 9/1/2003		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Compliance Status:
	Offline	2/1/2025 - 2/28/2025	n/a
	Offline	3/1/2025 - 3/31/2025	n/a
	Offline	4/1/2025 - 4/30/2025	n/a
		5/1/2025 - 5/31/2025	Y
		6/1/2025 - 6/30/2025	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090011	BETHEL WATER DEPT	C	9,507	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			3,300				

Towns Served: BETHEL, DANBURY

Water System Facility: CHESTNUT RIDGE FILTER PLANT (WSFID: 9)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 1/1/2005		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Operating Limit Compliance Status:
	Offline	2/1/2025 - 2/28/2025	n/a
	Offline	3/1/2025 - 3/31/2025	n/a
	Offline	4/1/2025 - 4/30/2025	n/a
	Offline	5/1/2025 - 5/31/2025	n/a
		6/1/2025 - 6/30/2025	Y

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 1/1/2005		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Operating Limit Compliance Status:
	Offline	2/1/2025 - 2/28/2025	n/a
	Offline	3/1/2025 - 3/31/2025	n/a
	Offline	4/1/2025 - 4/30/2025	n/a
	Offline	5/1/2025 - 5/31/2025	n/a
		6/1/2025 - 6/30/2025	Y

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2010	
CROSS CONNECTION SURVEY REPORT	3/1/2025	
CERTIFY LEAD SL NOTIFICATION	7/1/2025	11/14/2024
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CERTIFY LEAD SL NOTIFICATION	7/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule	Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00500	RAW SURFACE WATER ENTRY POINT - CHESTNUT	1	RAW EP - CHESTNUT	A				
00501	RAW SURFACE WATER ENTRY POINT - EUREKA	1	RAW EP - EUREKA	A				
00502	RAW WELLFIELD ENTRY POINT	2	RAW EP - WELLFIELD	A				
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		ALCS61	36 HIGHLAND AVENUE	A	Y	1		
		ALCS62	78 KINGSWOOD DRIVE	A	Y	2		
		ALCS63	92 KINGSWOOD DRIVE	A	Y	2		
		ALCS64	98 KINGSWOOD DRIVE	A	Y	2		
		ASWS11	10 NASHVILLE RD	A	Y			
ASWS12	12 MANSFIELD ST	A	Y					

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090011	BETHEL WATER DEPT	C	9,507	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			3,300				

Towns Served: BETHEL, DANBURY

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		ASWS13	6 SYMPAUG PARK RD	A	Y			
		ASWS14	17 TROWBRIDGE DR	A	Y			
		ASWS15	81 GREENWOOD AVE	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		GWS02	24 GRASSEY PLAIN STE	A	Y			
		GWS03	1 SCHOOL ST	A	Y			
		GWS04	600 WHITLESEY DR	A	Y			
		GWS05	185 GRASSEY PLAIN ST	I	Y			
		GWS06	36 SOUTH ST	A	Y			
		GWS07	1 KINGSWOOD DR	A	Y			
		GWS08	SUMMIT ROAD	A	Y			
		GWS11	154 GRASSEY PLAIN	A	Y			Y
		LCS21	9 SHARON CT	A	Y	1		
		LCS22	1 VERA ST	A	Y	1		
		LCS23	19 SHARON CT	A	Y	1		
		LCS24	80 KINGSWOOD DR	A	Y	2		
		LCS25	76 KNOLLWOOD DR	A	Y	2		
		LCS26	2 PUTNAM PARK RD	A	Y	1		
		LCS27	40 NASHVILLE RD	A	Y	1		
		LCS28	76 KINGSWOOD DR	A	Y	2		
		LCS29	55B KNOLLWOOD DRIVE	A	Y	2		
		LCS30	80 HOYT'S HILL ROAD	A	Y	1		
		LCS31	83 NASHVILLE ROAD	A	Y	1		
		LCS32	5 MAIN STREET #24	A	Y	2		
		LCS33	91 NASHVILLE ROAD	A	Y	1		
		LCS34	12 HIGHVIEW TERRACE	A	Y	1		
		LCS35	21 SHARON COURT	A	Y	1		
		LCS36	14 MILWAUKEE AVENUE	A	Y	1		
		LCS37	7 KAYVIEW AVENUE	A	Y	1		
		LCS38	49 NATURE VIEW TRAIL	A	Y	2		
		LCS39	8 HIGHVIEW TERRACE	A	Y	1		
		LCS40	51 NATURE VIEW TRAIL	A	Y	2		
		LCS41	66 GREENWOOD AVENUE	A	Y	1		
		LCS42	30 HIGHLAND AVENUE	A	Y	1		
		LCS43	24B RESERVOIR STREET	A	Y	1		
		LCS44	10 WHITLOCK AVENUE	A	Y	1		
		LCS45	53A KNOLLWOOD DRIVE	A	Y	2		
		LCS46	57 KNOLLWOOD DRIVE	A	Y	2		
		LCS47	12 BENSON ROAD	A	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090011	BETHEL WATER DEPT	C	9,507	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			3,300				

Towns Served: BETHEL, DANBURY

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		LCS48	43B PLUMTREES ACRES	A	Y	2		
		LCS49	45B PLUMTREES ACRES	A	Y	2		
		LCS50	7 MAIN STREET #2	A	Y	2		
		LCS51	27 DEER RUN TRAIL	A	Y	2		
		LCS52	33 DEER RUN TRAIL	A	Y	2		
		LCS53	34 IDLEWOOD DRIVE	A	Y	2		
		LCS54	38 IDLEWOOD DRIVE	A	Y	2		
		LCS55	44 IDLEWOOD DRIVE	A	Y	2		
		LCS56	52 NATURE VIEW TRAIL	A	Y	2		
		LCS57	60 NATURE VIEW TRAIL	A	Y	2		
		LCS58	55 KINGSWOOD DRIVE	A	Y	2		
		LCS59	65 KINGSWOOD DRIVE	A	Y	2		
		LCS60	71 KINGSWOOD DRIVE	A	Y	2		
		SWS01	RESERVOIR ST P.S.	A	Y			
		SWS08	44 CHESTNUT ST	I	Y			Y
		SWS09	SPRING HILL P.S	A	Y			Y
		SWS10	24 DODGINGTOWN RD	A	Y			Y
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		WGWS02	GENERATED BY BATCH	A	Y			
		WGWS03	GENERATED BY BATCH	A	Y			
		WGWS04	GENERATED BY BATCH	A	Y			
		WGWS06	GENERATED BY BATCH	A	Y			
		WGWS07	GENERATED BY BATCH	A	Y			
		WGWS08	GENERATED BY BATCH	A	Y			
		WGWS11	GENERATED BY BATCH	A	Y			
		WSWS01	GENERATED BY BATCH	A	Y			
		WSWS09	GENERATED BY BATCH	A	Y			
		WSWS10	GENERATED BY BATCH	A	Y			
		WSWS11	GENERATED BY BATCH	A	Y			
00700	ENTRY POINT 1 - CHESTNUT RIDGE	3	EP - CHESTNUT RIDGE	A				
00701	ENTRY POINT 2 - EUREKA	3	EP - EUREKA	A				
00702	ENTRY POINT - MAPLE AVE WELLS	3	EP - MAPLE AVE WELLS	A				
10	EUREKA FILTER PLANT	3	ENTRY POINT - EUREKA	A				
		5	COMBINED FILTER EFFL	A				
1370	MAPLE AVE WELL 1	2	MAPLE AVE WELL 1	A				
1371	MAPLE AVE WELL 2	2	MAPLE AVE WELL 2	A				
2001	CHESTNUT RIDGE RESERVOIR	1	CHESTNUT RIDGE RES	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090011	BETHEL WATER DEPT	C	9,507	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			3,300				

Towns Served: BETHEL, DANBURY

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
2002	MOUNTAIN POND	1	MOUNTAIN POND	A				
2003	EUREKA LAKE	1	EUREKA LAKE	A				
30013	EUREKA LAKE RESERVOIR INTAKE							
30014	CHESTNUT RIDGE RESERVOIR INTAKE							
46156	MAPLE AVE WELLS TREATMENT PLANT							
51610	CHESTNUT RIDGE CLEARWELLS							
51612	EUREKA WTP CLEARWELLS							
51616	HOYTS HILL BOOSTER STATION							
51618	HOYTS HILL STORAGE TANK							
51621	THE SUMMIT - LOWER PS							
51622	THE SUMMIT - UPPER PS							
58071	INTERCONNECTION - CT0340011 - DANBURY							
59921	SOUTH STREET PUMP STATION							
60721	MAPLE AVE WELL 1A	2	MAPLE AVE - WELL 1A	A				
60723	MAPLE AVE WELL 2A	2	MAPLE AVE - WELL 2A	A				
61053	EUREKA LAKE WATER STORAGE TANK							
61176	BRIAR CLIFF PUMP STATION							
62320	CHESTNUT RIDGE STORAGE TANK							
62322	SUMMIT ATMOSPHERIC TANK							
9	CHESTNUT RIDGE FILTER PLANT	3	ENTRY POINT - CHESTN	A				
		5	COMBINED FILTER EFFL	A				

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: CLASS 2 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
CURTIS, KELLY D.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2025
MCCOLLAM, CHRISTOPHER C.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2027 6/30/2028

Water System Facility: CHESTNUT RIDGE FILTER PLANT (WSF ID: 9)

Facility Classification: CLASS 3 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
BECHTOLD, JUSTIN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2026 6/30/2027

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090011	BETHEL WATER DEPT	C	9,507	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			3,300				

Towns Served: BETHEL, DANBURY

Certified Operator Information

Water System Facility: **CHESTNUT RIDGE FILTER PLANT (WSF ID: 9)**

Facility Classification: CLASS 3 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
MCCOLLAM, CHRISTOPHER C.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2027
		WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2028

Water System Facility: **EUREKA FILTER PLANT (WSF ID: 10)**

Facility Classification: CLASS 3 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
BECHTOLD, JUSTIN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2027
MCCOLLAM, CHRISTOPHER C.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2027
		WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2028

Water System Facility: **MAPLE AVE WELLS TREATMENT PLANT (WSF ID: 46156)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
BECHTOLD, JUSTIN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2027
MCCOLLAM, CHRISTOPHER C.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2027
		WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2028

Contact Information

Name		Organization			Job Title	
Mr. Thomas F. Villa		Town of Bethel			Public Utilities Dir	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
1 School Street				Bethel	CT	06801
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-794-8557		203-794-8767		203-313-9982	villat@bethel-ct.gov	

Contact Role(s): **Administrative Contact**

Name		Organization			Job Title	
Mr. Dan Carter		Bethel Water Department			First Selectman	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
1 School St				Bethel	CT	06801
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-794-8501		203-778-7502			carterd@bethel-ct.gov	

Contact Role(s): **Legal Contact**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090011	BETHEL WATER DEPT	C	9,507	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			3,300				

Towns Served: BETHEL, DANBURY

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090114	ELMWOOD COURT, LLC	C	54	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3			

Towns Served: BETHEL

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28				
Total Coliform (3100)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25		Complete		
	5/1/25 - 5/31/25		Complete		
	6/1/25 - 6/30/25		Complete		
	7/1/25 - 7/31/25				
	8/1/25 - 8/31/25				
	9/1/25 - 9/30/25				
	10/1/25 - 10/31/25				
	11/1/25 - 11/30/25				
	12/1/25 - 12/31/25				
Disinfectant Byproducts - TTHM & HAA5 (DBP)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/25				
	1/1/26 - 12/31/26				
Lead And Copper (PBCU)		5 routine (RT) per six months			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/25 - 6/30/25		Complete		
	7/1/25 - 12/31/25				
Physical Parameters (PPS)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25		Complete		
	5/1/25 - 5/31/25		Complete		
	6/1/25 - 6/30/25		Complete		
	7/1/25 - 7/31/25				
	8/1/25 - 8/31/25				
	9/1/25 - 9/30/25				
	10/1/25 - 10/31/25				
	11/1/25 - 11/30/25				
	12/1/25 - 12/31/25				

Water System Facility: **ENTRY POINT WELL #1 & #2 (WSF ID: 00700)**

Nitrate (1040)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090114	ELMWOOD COURT, LLC	C	54	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3			

Towns Served: BETHEL

Monitoring Requirements

Water System Facility: ENTRY POINT WELL #1 & #2 (WSF ID: 00700)

Nitrate (1040)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL #1 (3)	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL #1 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL #1 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL #1 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL #1 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL #1 (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL #1 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL #1 (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility: WELL #1 (WSF ID: 1905)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL (2)	2/1/25 - 2/28/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090114	ELMWOOD COURT, LLC	C	54	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3			

Towns Served: BETHEL

Monitoring Requirements

Water System Facility: **WELL #1 (WSF ID: 1905)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		

Water System Facility: **WELL #2 (WSF ID: 1906)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #2 (2)	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SWTS 2: DWS REVIEW & APPROVAL OF SOWT		
CCTS 2: DWS REVIEW & APPROVAL OF OCCT		
CCTS 1: PWS TO RECOMMEND OCCT	1/3/2022	
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	
SUBMIT CCR CERTIFICATION FORM	8/9/2025	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	9/28/2025	
CROSS CONNECTION EXEMPTION	3/1/2026	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090114	ELMWOOD COURT, LLC	C	54	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3			

Towns Served: BETHEL

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		EC001	BUILDING 83 NUMB 1	A	Y	2	Y	
		EC002	BUILDING 83 NUMB 2	A	Y	2	Y	
		EC003	BUILDING 83 NUMB 3	A	Y	2	Y	
		EC004	BUILDING 83 NUMB 4	A	Y	2	Y	Y
		EC005	BUILDING 83 NUMB 5	A	Y	2	Y	
		EC006	BUILDING 83 NUMB 6	A	Y	2	Y	
		EC007	BUILDING 83 NUMB 7	A	Y	2	Y	
		EC008	BUILDING 83 NUMB 8	A	Y	2	Y	
		EC009	BUILDING NUMB 81	A	Y	2	Y	
		EC010	BUILDING 79 NUMB 1	A	Y	2	Y	
		EC011	BUILDING 79 NUMB 2	A	Y	2	Y	
		EC012	BUILDING 79 NUMB 3	A	Y	2	Y	
		EC013	BUILDING 79 NUMB 4	A	Y	2	Y	
		EC014	BUILDING 79 NUMB 5	A	Y	2	Y	
		EC015	BUILDING 79 NUMB 6	A	Y	2	Y	
		EC016	BUILDING 79 NUMB 7	A	Y	2	Y	
		EC017	BUILDING 79 NUMB 8	A	Y	2	Y	
		EC018	BULDING 77 NUMB 1	A	Y	2	Y	
		EC019	BULDING 77 NUMB 2	A	Y	2	Y	
		EC020	BULDING 77 NUMB 3	A	Y	2	Y	
		EC021	BULDING 77 NUMB 4	A	Y	2	Y	
		EC022	BUILDING 73 NUMB 1	A	Y	2	Y	
		EC023	BUILDING 73 NUMB 2	A	Y	2	Y	
		EC024	BUILDING 73 NUMB 3	A	Y	2	Y	
		EC025	BUILDING 73 NUMB 4	A	Y	2	Y	
		EC026	BUILDING 73 NUMB 5	A	Y	2	Y	
		EC027	APARTMENT 5	A	Y	2	Y	
		EC028	LEAD COPPER APT 4	A	Y	2		
		EC029	LOT 81 C/L	A	Y	2	Y	
		EC030	APT 2 LOT 83	A	Y	2	Y	
		OFFSINK	OFFICE SINK	I	Y	2	Y	
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT WELL #1 & #2	3	ENTRY POINT WELL #1	A				
1905	WELL #1	2	WELL	A				
1906	WELL #2	2	WELL #2	A				
63123	TREATMENT PLANT							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0090114	ELMWOOD COURT, LLC	C	54	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3			

Towns Served: BETHEL

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
HURLBUT, PAUL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2025

Contact Information

Name		Organization			Job Title	
Mr. Gregory M. Kallas					Member	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
5 Bernlou Drive				Danbury	CT	06811
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-733-1983				203-792-6876	gregorykallas@gmail.com	

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule