

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (1012)	50 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/21 - 12/31/29		
Total Coliform (3100)	50 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
Disinfectant Byproducts - TTHM & HAA5 (DBP)	4 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
2279 MT VERNON RD (SMP0004)	1/1/25 - 3/31/25	2/1-2/28	Complete
	4/1/25 - 6/30/25	5/1-5/31	Complete
	7/1/25 - 9/30/25	8/1-8/31	
	10/1/25 - 12/31/25	11/1-11/30	
252 MARION AVENUE (SWD0003)	1/1/25 - 3/31/25	2/1-2/28	Complete
	4/1/25 - 6/30/25	5/1-5/31	Complete
	7/1/25 - 9/30/25	8/1-8/31	
	10/1/25 - 12/31/25	11/1-11/30	
6 CARTER LANE (SWD0021)	1/1/25 - 3/31/25	2/1-2/28	Complete
	4/1/25 - 6/30/25	5/1-5/31	Complete
	7/1/25 - 9/30/25	8/1-8/31	
	10/1/25 - 12/31/25	11/1-11/30	
2321 MERIDEN WTBY RD (SWD0022)	1/1/25 - 3/31/25	2/1-2/28	Complete
	4/1/25 - 6/30/25	5/1-5/31	Complete
	7/1/25 - 9/30/25	8/1-8/31	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Disinfectant Byproducts - TTHM & HAA5 (DBP) 4 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	10/1/25 - 12/31/25	11/1-11/30	

Lead And Copper (PBCU) 30 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/26	6/1-9/30	
	1/1/27 - 12/31/29	6/1-9/30	

Physical Parameters (PPS) 50 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		

Water System Facility: **SOUTHINGTON FP - ENTRY POINT (WSF ID: 00700)**

Net Gross Alpha (4000) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SOUTHINGTON FP (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Uranium (4006) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SOUTHINGTON FP (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Combined Radium-226/228 (4010) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SOUTHINGTON FP (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Inorganic Chemicals (IOCS) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SOUTHINGTON FP (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Nitrate And Nitrite (NOX) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Monitoring Requirements

Water System Facility: **SOUTHINGTON FP - ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SOUTHINGTON FP (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS) 2 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SOUTHINGTON FP (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SOUTHINGTON FP (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Water System Facility: **ENTRY POINT - WELL 1A (WSF ID: 00701)**

Net Gross Alpha (4000) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1A (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Uranium (4006) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1A (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Combined Radium-226/228 (4010) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1A (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Gross Beta Particle Activity (4100) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1A (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Man-Made Beta Particle & Photon Emitters (4101) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1A (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Tritium (4102) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1A (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Monitoring Requirements

Water System Facility: ENTRY POINT - WELL 1A (WSF ID: 00701)

Strontium-90 (4174) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1A (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Inorganic Chemicals (IOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1A (3)	1/1/24 - 12/31/26		Complete
	1/1/27 - 12/31/29		

Nitrate And Nitrite (NOX) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1A (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS) 2 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1A (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1A (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Water System Facility: ENTRY POINT - WELLS 2 & 2A (WSF ID: 00702)

Inorganic Chemicals (IOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 2 & 2A (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Nitrate And Nitrite (NOX) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 2 & 2A (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 2 & 2A (3)	1/1/24 - 12/31/26		Complete
	1/1/27 - 12/31/29		

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 2 & 2A (3)	1/1/24 - 12/31/26		Complete
	1/1/27 - 12/31/29		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Monitoring Requirements

Water System Facility: ENTRY POINT - WELLS 2 & 2A (WSF ID: 00702)

Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 2 & 2A (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Water System Facility: ENTRY POINT - WELL 3 (WSF ID: 00703)

Nitrate (1040)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 3 (3)	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Nitrite (1041)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 3 (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 3 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 3 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 3 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Gross Beta Particle Activity (4100)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 3 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Man-Made Beta Particle & Photon Emitters (4101)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 3 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Tritium (4102)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 3 (3)	1/1/23 - 12/31/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Monitoring Requirements

Water System Facility: **ENTRY POINT - WELL 3 (WSF ID: 00703)**

Tritium (4102)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 12/31/28		
Strontium-90 (4174)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 3 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 3 (3)	1/1/24 - 12/31/26		Complete
	1/1/27 - 12/31/29		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 3 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 3 (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Water System Facility: **ENTRY POINT - WELLS 7 & 7A (WSF ID: 00704)**

Metolachlor (2045)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - WELLS 7 & 7A (3)	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - WELLS 7 & 7A (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - WELLS 7 & 7A (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - WELLS 7 & 7A (3)	1/1/25 - 12/31/27		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Monitoring Requirements

Water System Facility: ENTRY POINT - WELLS 7 & 7A (WSF ID: 00704)

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS) 2 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - WELLS 7 & 7A (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - WELLS 7 & 7A (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Water System Facility: ENTRY POINT - WELL 8 (WSF ID: 00705)

Net Gross Alpha (4000) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 8 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Uranium (4006) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 8 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Combined Radium-226/228 (4010) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 8 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Inorganic Chemicals (IOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 8 (3)	1/1/24 - 12/31/26		Complete
	1/1/27 - 12/31/29		

Nitrate And Nitrite (NOX) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 8 (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS) 2 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 8 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 8 (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Monitoring Requirements

Water System Facility: **ENTRY POINT - WELL 9 (WSF ID: 00706)**

Net Gross Alpha (4000)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - WELL 9 (3)	1/1/23 - 12/31/25		Complete		
	1/1/26 - 12/31/28				
Uranium (4006)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - WELL 9 (3)	1/1/23 - 12/31/25		Complete		
	1/1/26 - 12/31/28				
Combined Radium-226/228 (4010)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - WELL 9 (3)	1/1/23 - 12/31/25		Complete		
	1/1/26 - 12/31/28				
Inorganic Chemicals (IOCS)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - WELL 9 (3)	1/1/24 - 12/31/26		Complete		
	1/1/27 - 12/31/29				
Nitrate And Nitrite (NOX)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - WELL 9 (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25				
	1/1/26 - 12/31/26				
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		2 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - WELL 9 (3)	1/1/23 - 12/31/25		Complete		
	1/1/26 - 12/31/28				
Organic Chemicals (VOCS)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - WELL 9 (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25				
	1/1/26 - 12/31/26				
Water System Facility: WELL 8 (WSF ID: 1170)					
E. Coli (3014)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
WELL 8 (2)	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25		Complete		
	5/1/25 - 5/31/25		Complete		
	6/1/25 - 6/30/25		Complete		
	7/1/25 - 7/31/25		Complete		
	8/1/25 - 8/31/25		Complete		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Monitoring Requirements

Water System Facility: **WELL 8 (WSF ID: 1170)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		

Water System Facility: **WELL 1A (WSF ID: 1172)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 1A (2)	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		

Water System Facility: **WELL 3 (WSF ID: 1173)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 3 (2)	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		

Water System Facility: **WELL 9 (WSF ID: 1451)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 9 (2)	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Monitoring Requirements

Water System Facility: **WELL 9 (WSF ID: 1451)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		

Water System Facility: **SOUTHINGTON RESERVOIR #1 (WSF ID: 2235)**

Total Alkalinity (1927)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SOUTHINGTON RESERVOIR #1 (1)	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SOUTHINGTON RESERVOIR #1 (1)	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		

Surface Water Inorganic Chemicals (RIOCI)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SOUTHINGTON RESERVOIR #1 (1)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Surface Water Color and Turbidity (RPPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SOUTHINGTON RESERVOIR #1 (1)	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Surface Water Pesticides (RSOC)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SOUTHINGTON RESERVOIR #1 (1)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Monitoring Requirements

Water System Facility: **SOUTHINGTON RESERVOIR #3 (WSF ID: 2237)**

Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SOUTHINGTON RESERVOIR #3 (1)	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Surface Water Inorganic Chemicals (RIOC)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SOUTHINGTON RESERVOIR #3 (1)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Surface Water Color and Turbidity (RPPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SOUTHINGTON RESERVOIR #3 (1)	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Surface Water Pesticides (RSOC)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SOUTHINGTON RESERVOIR #3 (1)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility: **SOUTHINGTON FILTER PLANT (WSF ID: 310)**

Total Organic Carbon (2920)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SOUTHINGTON FP (5)	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		

Water System Facility: **WELL 7A (WSF ID: 60726)**

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 7A (2)	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Monitoring Requirements

Water System Facility: **WELL 7A (WSF ID: 60726)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		

Water System Facility: **WELL 2A (WSF ID: 61740)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 2A (2)	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **SOUTHINGTON FP - ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 5/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 5/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	2/1/2025 - 2/28/2025	Y	
	3/1/2025 - 3/31/2025	Y	
	4/1/2025 - 4/30/2025	Y	
	5/1/2025 - 5/31/2025	Y	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Water System Facility: **SOUTHINGTON FP - ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 5/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		6/1/2025 - 6/30/2025	Compliance Status:

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.8 PH	Daily
Start Date: 7/1/2003		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
		5/1/2025 - 5/31/2025	
		6/1/2025 - 6/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 3 MG/L	2
Start Date: 7/1/2003		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
		5/1/2025 - 5/31/2025	
		6/1/2025 - 6/30/2025	

Water System Facility: **ENTRY POINT - WELL 1A (WSFID: 00701)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.53 MG/L	Daily
Start Date: 6/1/2010		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
		5/1/2025 - 5/31/2025	
		6/1/2025 - 6/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 5/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
		5/1/2025 - 5/31/2025	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Water System Facility: ENTRY POINT - WELL 1A (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 5/1/2023			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	6/1/2025 - 6/30/2025		
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 5/1/2023			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		

Water System Facility: ENTRY POINT - WELLS 2 & 2A (WSFID: 00702)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2020			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 5/1/2023			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 5/1/2023			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		
	5/1/2025 - 5/31/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Water System Facility: ENTRY POINT - WELL 3 (WSFID: 00703)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 5/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		6/1/2025 - 6/30/2025	Compliance Status:

Water System Facility: ENTRY POINT - WELLS 7 & 7A (WSFID: 00704)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 10/1/2017		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
		5/1/2025 - 5/31/2025	
		6/1/2025 - 6/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 5/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
		5/1/2025 - 5/31/2025	
		6/1/2025 - 6/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 5/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		2/1/2025 - 2/28/2025	Y
		3/1/2025 - 3/31/2025	Y
		4/1/2025 - 4/30/2025	Y
		5/1/2025 - 5/31/2025	Y
		6/1/2025 - 6/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 10/1/2017		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
		5/1/2025 - 5/31/2025	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Water System Facility: ENTRY POINT - WELLS 7 & 7A (WSFID: 00704)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 10/1/2017		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		6/1/2025 - 6/30/2025	Compliance Status:

Water System Facility: ENTRY POINT - WELL 8 (WSFID: 00705)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 5/1/2005		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
		5/1/2025 - 5/31/2025	
		6/1/2025 - 6/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 5/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
		5/1/2025 - 5/31/2025	
		6/1/2025 - 6/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 5/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		2/1/2025 - 2/28/2025	Y
		3/1/2025 - 3/31/2025	Y
		4/1/2025 - 4/30/2025	Y
		5/1/2025 - 5/31/2025	Y
		6/1/2025 - 6/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 3 MG/L	2
Start Date: 1/1/2002		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
		5/1/2025 - 5/31/2025	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Water System Facility: ENTRY POINT - WELL 8 (WSFID: 00705)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 3 MG/L	2
Start Date: 1/1/2002		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		6/1/2025 - 6/30/2025	

Water System Facility: ENTRY POINT - WELL 9 (WSFID: 00706)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 5/1/2005		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
		5/1/2025 - 5/31/2025	
		6/1/2025 - 6/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 5/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
		5/1/2025 - 5/31/2025	
		6/1/2025 - 6/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 5/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		2/1/2025 - 2/28/2025	Y
		3/1/2025 - 3/31/2025	Y
		4/1/2025 - 4/30/2025	Y
		5/1/2025 - 5/31/2025	Y
		6/1/2025 - 6/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 3 MG/L	2
Start Date: 10/1/2003		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
		5/1/2025 - 5/31/2025	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Water System Facility: ENTRY POINT - WELL 9 (WSFID: 00706)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 3 MG/L	2
Start Date: 10/1/2003		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		6/1/2025 - 6/30/2025	Compliance Status:

Water System Facility: SOUTHINGTON FILTER PLANT (WSFID: 310)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2002		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		2/1/2025 - 2/28/2025	Y
		3/1/2025 - 3/31/2025	Y
		4/1/2025 - 4/30/2025	Y
		5/1/2025 - 5/31/2025	Y
		6/1/2025 - 6/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 1/1/2002		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		2/1/2025 - 2/28/2025	Y
		3/1/2025 - 3/31/2025	Y
		4/1/2025 - 4/30/2025	Y
		5/1/2025 - 5/31/2025	Y
		6/1/2025 - 6/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 1/1/2002		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		2/1/2025 - 2/28/2025	Y
		3/1/2025 - 3/31/2025	Y
		4/1/2025 - 4/30/2025	Y
		5/1/2025 - 5/31/2025	Y
		6/1/2025 - 6/30/2025	

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
CROSS CONNECTION SURVEY REPORT	3/1/2025	
CERTIFY LEAD SL NOTIFICATION	7/1/2025	6/27/2025
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CERTIFY LEAD SL NOTIFICATION	7/1/2026	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		4-1	FLANDERS SCHOOL	A	Y			
		4-2	HATTON SCHOOL	A	Y			
		4-3	KELLEY SCHOOL	A	Y			
		4-4	JW MUNICIPAL CENTER	A	Y			
		4-5	SOUTH END SCHOOL	A	Y			
		4-6	STRONG SCHOOL	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		S-15	WELL 3 RAW/HOBART ST	A	Y			
		SMP0004	2279 MT VERNON RD	A	Y			Y
		SMP004	2279 MT. VERNON RD	A	Y			
		SWD0001	200 EXECUTIVE BLVD	I	Y			
		SWD0002	570 MAIN STREET	I	Y			
		SWD0003	252 MARION AVENUE	A	Y			Y
		SWD0004	1237 MARION AVENUE	A	Y			Y
		SWD0005	1156 M.W.T.	A	Y			
		SWD0006	65 AMATO CIRCLE	I	Y			
		SWD0007	88 BERLIN STREET	A	Y			
		SWD0008	460 PLEASANT STREET	I	Y			
		SWD0009	408 QUEEN STREET	A	Y			
		SWD0010	50 RIVER STREET	A	Y			
		SWD0011	246 REDSTONE STREET	A	Y			
		SWD0012	FILTER PLANT	A				
		SWD0013	ST DOMINIC'S CHURCH	A				
		SWD0014	FLANDERS SCHOOL	A			Y	
		SWD0015	DEPAULO SCHOOL	A				
		SWD0016	TRUCK STOP	A				
		SWD0017	LAKE COMPOUNCE PARK	A				
		SWD0018	388 PLEASANT STREET	A	Y			
		SWD0019	620 MAIN STREET	I	Y			
		SWD0020	1131 WEST STREET	A	Y			
		SWD0021	6 CARTER LANE	A	Y			Y
		SWD0022	2321 MERIDEN WTBY RD	A	Y			
		SWD0A01	KELLEY SCHOOL	A			Y	
		SWD0A02	HATTON SCHOOL	A			Y	
		SWD0A03	SOUTH END SCHOOL	A			Y	
		SWD0A04	JW MUNICIPAL CENTER	A			Y	
		SWD0A05	STRONG SCHOOL	A			Y	
		SWDLC01	29 AMANDA LANE	I	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		SWDLC02	37 AMANDA LANE	A	Y	1		
		SWDLC03	48 AMANDA LANE	I	Y	1		
		SWDLC04	54 AMATO CIRCLE	I	Y	1		
		SWDLC05	64 AMATO CIRCLE	I	Y	1		
		SWDLC06	65 AMATO CIRCLE	I	Y	1		
		SWDLC07	289 ANNE LISE AVENUE	A	Y	1		
		SWDLC08	93 BISHOP AVENUE	A	Y	1		
		SWDLC09	27 BRIGHTWOOD LANE	A	Y	1		
		SWDLC10	73 BRIGHTWOOD LANE	I	Y	1		
		SWDLC100	56 CARTER LN	A	Y	1		
		SWDLC101	53 ELM ST	A		1		
		SWDLC102	81 GROVE ST	A		1		
		SWDLC103	47 HIGHWOOD AVE	A		1		
		SWDLC104	55 HOMESDALE AVE	A		1		
		SWDLC105	30 KNOX DR	A		1		
		SWDLC106	5 LACEY RD	A		1		
		SWDLC107	38 MACARTHUR DR	A		1		
		SWDLC108	128 MERIDEN AVE	A		1		
		SWDLC109	291 MERIDEN AVE	A		1		
		SWDLC11	93 BUCKLAND STREET	A	Y	1		
		SWDLC110	1585 MWT	A		1		
		SWDLC111	57 MERRELL AVE	A		1		
		SWDLC112	82 NORTON ST	A		1		
		SWDLC113	67 OAKLAND RD	A		1		
		SWDLC114	327 SOUTH END RD	A		1		
		SWDLC115	972 SOUTH MAIN ST	A		1		
		SWDLC116	106 SUMMER ST	A		1		
		SWDLC117	73 SUNNYRIDGE DR	A		1		
		SWDLC118	18 TAUNTON ST	A		1		
		SWDLC119	31 VERMONT TERRACE	A		1		
		SWDLC12	163 BUTTERNUT LANE	A	Y	1		
		SWDLC120	164 WEST MAIN ST	A		1		
		SWDLC121	167 WONX SPRING RD	A		1		
		SWDLC13	29 CANTERBURY LANE	A	Y	1		
		SWDLC14	130 CICCOLELLA COURT	A	Y	1		
		SWDLC15	140 CREST ROAD	A	Y	1		
		SWDLC16	54 DAYTON DRIVE	A	Y	1		
		SWDLC17	197 DECKERT DRIVE	I	Y	1		
		SWDLC18	73 DEERBROOKE CRICLE	I	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		SWDLC19	93 DOE MEADOW COURT	I	Y	1		
		SWDLC20	105 DOE MEADOW COURT	A	Y	1		
		SWDLC21	54GALLANT DRIVE	A	Y	1		
		SWDLC22	87 GREAT PINE PATH	A	Y	1		
		SWDLC23	28 GREENWOOD DRIVE	I	Y	1		
		SWDLC24	50 GREENWOOD DRIVE	I	Y	1		
		SWDLC25	6 GREYSTONE DRIVE	I	Y	1		
		SWDLC26	20 GREYSTONE DRIVE	I	Y	1		
		SWDLC27	32 GREYSTOE DRIVE	I	Y	1		
		SWDLC28	50 GREYSTONE DRIVE	A	Y	1		
		SWDLC29	51 GREYSTONE DRIVE	A	Y	1		
		SWDLC30	78 GREYSTONE DRIVE	A	Y	1		
		SWDLC31	105 GREYSTONE DRIVE	I	Y	1		
		SWDLC32	461 HART STREET	A	Y	1		
		SWDLC33	82 HOLLY HILL DRIVE	A	Y	1		
		SWDLC34	96 HOLLY HILL DRIVE	A	Y	1		
		SWDLC35	139 HUCKLEBERRY LANE	A	Y	1		
		SWDLC36	192 LEPAGE DRIVE	A	Y	1		
		SWDLC37	24 MARK DRIVE	A	Y	1		
		SWDLC38	50 MARK DRIVE	I	Y	1		
		SWDLC39	580 MOUNT VERNON RD	A	Y	1		
		SWDLC40	10 NUNZIO DRIVE	I	Y	1		
		SWDLC41	50 NUNZIO DRIVE	A	Y	1		
		SWDLC42	64 NUNZIO DRIVE	I	Y	1		
		SWDLC43	65 NUNZIO DRIVE	I	Y	1		
		SWDLC44	74 NUNZIO DRIVE	A	Y	1		
		SWDLC45	75 NUNZIO DRIVE	I	Y	1		
		SWDLC46	85 NUNZIO DRIVE	A	Y	1		
		SWDLC47	95 NUNZIO DRIVE	I	Y	1		
		SWDLC48	105 NUNZIO DRIVE	I	Y	1		
		SWDLC49	110 NUNZIO DRIVE	I	Y	1		
		SWDLC50	120 NUNZIO DRIVE	A	Y	1		
		SWDLC51	57 ROXBURY ROAD	I	Y	1		
		SWDLC52	57 ROXBURY ROAD	A	Y	1		
		SWDLC53	21 ROYAL OAK DRIVE	I	Y	1		
		SWDLC54	20 SUNSET RIDGE	I	Y	1		
		SWDLC55	96 WOODBERRY HILL DR	A	Y	1		
		SWDLC56	50 NUNZIO DRIVE	I		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		SWDLC57	74 NUNZIO DRIVE	A		1		
		SWDLC58	85 NUNZIO DRIVE	I		1		
		SWDLC59	95 NUNZIO DRIVE	I		1		
		SWDLC60	110 NUNZIO DRIVE	I		1		
		SWDLC61	120 NUNZIO DRIVE	I		1		
		SWDLC62	21 BELLEVIEW AVE	A		1		
		SWDLC63	33 BERKLEY AVE	A		1		
		SWDLC64	49 BERKLEY AVE	A		1		
		SWDLC65	87 BERLIN ST	A		1		
		SWDLC66	148 BERLIN ST	A		1		
		SWDLC67	265 BRISTOL ST	A		1		
		SWDLC68	25 BURWELL AVE	A		1		
		SWDLC69	79 GROVE ST	A		1		
		SWDLC70	118 HIGHWOOD AVE	A		1		
		SWDLC71	49 HOMESDALE AVE	A		1		
		SWDLC72	31 KNOX DR	A		1		
		SWDLC73	37 LACEY RD	A		1		
		SWDLC74	224 MARION AVE	A		1		
		SWDLC75	27 MACARTHUR DR	A		1		
		SWDLC76	243 MERIDEN AVE	A		1		
		SWDLC77	622 MWT	A		1		
		SWDLC78	38 MERRELL AVE	A		1		
		SWDLC79	312 MILL ST	A		1		
		SWDLC80	51 OAK ST	A		1		
		SWDLC81	80 OAKLAND RD	A		1		
		SWDLC82	101 OAKLAND RD	A		1		
		SWDLC83	1981 PECK LN	A		1		
		SWDLC84	387 SOUTH END RD	A		1		
		SWDLC85	974 SOUTH MAIN ST	A		1		
		SWDLC86	287 SUMMER ST	A		1		
		SWDLC87	165 SUMMIT ST	A		1		
		SWDLC88	42 TODD RD	A		1		
		SWDLC89	20 VERMONT AVE	A		1		
		SWDLC90	76 WILBUR ST	A		1		
		SWDLC91	161 WONX SPRING RD	A		1		
		SWDLC92	80 ACADEMY ST	A		1		
		SWDLC93	56 BELLEVIEW AVE	A		1		
		SWDLC94	25 BERKLEY AVE	A		1		
		SWDLC95	71 BERKLEY AVE	A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		SWDLC96	10 BERKLEY CT	A		1		
		SWDLC97	37 BERLIN ST	A		1		
		SWDLC98	131 BERLIN ST	A		1		
		SWDLC99	39 BURWELL AVE	A		1		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	SOUTHINGTON FP - ENTRY POINT	3	EP - SOUTHINGTON FP	A				
00701	ENTRY POINT - WELL 1A	3	EP - WELL 1A	A				
00702	ENTRY POINT - WELLS 2 & 2A	3	EP - WELLS 2 & 2A	A				
00703	ENTRY POINT - WELL 3	3	EP - WELL 3	A				
00704	ENTRY POINT - WELLS 7 & 7A	3	ENTRY POINT - WELLS	A				
00705	ENTRY POINT - WELL 8	3	EP - WELL 8	A				
00706	ENTRY POINT - WELL 9	3	EP - WELL 9	A				
1170	WELL 8	2	WELL 8	A				
1172	WELL 1A	2	WELL 1A	A				
1173	WELL 3	2	WELL 3	A				
1451	WELL 9	2	WELL 9	A				
2235	SOUTHINGTON RESERVOIR #1	1	SOUTHINGTON RESERVOI	A				
2236	SOUTHINGTON RESERVOIR #2	1	SOUTHINGTON RESERVOI	A				
2237	SOUTHINGTON RESERVOIR #3	1	SOUTHINGTON RESERVOI	A				
262	WELL #1A TREATMENT STATION	5	IESWTR - ENTRY POINT	A				
30082	RESERVOIR #3 INTAKE							
30084	RESERVOIR #1 INTAKE							
310	SOUTHINGTON FILTER PLANT	5	EP - SOUTHINGTON FP	A				
492	WELLS 2 & 2A TREATMENT STATION	5	IESWTR - ENTRY POINT	A				
493	WELL #3 TREATMENT STATION	5	IESWTR - ENTRY POINT	A				
494	WELL 7 & 7A TREATMENT STATION	5	IESWTR - ENTRY POINT	A				
495	WELL #8 TREATMENT STATION	5	IESWTR - ENTRY POINT	A				
496	WELL #9 TREATMENT STATION	5	IESWTR - ENTRY POINT	A				
50880	SOUTHINGTON FILTER PLANT STORAGE TANK							
50882	WEST QUEEN STREET TANK #1							
50884	WEST QUEEN STREET TANK #2							
50886	VILLAGE GATE STORAGE TANK							
54003	WEST QUEEN STREET BOOSTER STATION							
54005	SOUTHEAST PUMPING STATION							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
58145	MARIONDALE DR TANK (NEW)							
60726	WELL 7A	2	WELL 7A	A				
61043	INTERCONNECTION - CT0930011 - RWA							
61740	WELL 2A	2	WELL 2A	A				
62091	MILL STREET TANK							
62289	EAST SIDE WATER STORAGE BOOSTER STATION							
62291	EASTSIDE WATER STORAGE TANK							
XX704	ENTRY POINT - WELL 7	3X	EP - WELL 7	A				

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: CLASS 2 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
HEDMAN, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2026 9/30/2025
GEIS, JAMES D.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2025 12/31/2025

Water System Facility: WELL #1A TREATMENT STATION (WSF ID: 262)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
HEDMAN, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2026 9/30/2025
GEIS, JAMES D.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2025 6/30/2025
KARELUS, DARIUS	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2026
MONGILLO, JEREMY M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2025
DELSANTO, LORENZO J	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2027

Water System Facility: SOUTHINGTON FILTER PLANT (WSF ID: 310)

Facility Classification: CLASS 4 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
HEDMAN, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2026 9/30/2025
GEIS, JAMES D.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2025 6/30/2025
KARELUS, DARIUS	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2026
MONGILLO, JEREMY M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2025

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Certified Operator Information

Water System Facility: SOUTHINGTON FILTER PLANT (WSF ID: 310)

Facility Classification: CLASS 4 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
DELSANTO, LORENZO J	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2027

Water System Facility: WELLS 2 & 2A TREATMENT STATION (WSF ID: 492)

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
HEDMAN, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2026 9/30/2025
GEIS, JAMES D.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2025 6/30/2025
KARELUS, DARIUS	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2026
MONGILLO, JEREMY M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2025

Water System Facility: WELL #3 TREATMENT STATION (WSF ID: 493)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
HEDMAN, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2026 9/30/2025
GEIS, JAMES D.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2025 12/31/2025
KARELUS, DARIUS	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2026
MONGILLO, JEREMY M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2025

Water System Facility: WELL 7 & 7A TREATMENT STATION (WSF ID: 494)

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
HEDMAN, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2026 9/30/2025
GEIS, JAMES D.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2025 6/30/2025
KARELUS, DARIUS	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2026
MONGILLO, JEREMY M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2025
DELSANTO, LORENZO J	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2027

Water System Facility: WELL #8 TREATMENT STATION (WSF ID: 495)

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
HEDMAN, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2026 9/30/2025
GEIS, JAMES D.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2025 6/30/2025

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Certified Operator Information

Water System Facility: WELL #8 TREATMENT STATION (WSF ID: 495)

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
KARELUS, DARIUS	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2026
MONGILLO, JEREMY M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2025
DELSANTO, LORENZO J	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2027

Water System Facility: WELL #9 TREATMENT STATION (WSF ID: 496)

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
HEDMAN, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2026 9/30/2025
GEIS, JAMES D.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2025 6/30/2025
KARELUS, DARIUS	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2026
MONGILLO, JEREMY M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2025
DELSANTO, LORENZO J	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2027

Contact Information

Name		Organization			Job Title	
Mr. Albert T Fiorillo		Southington Water Department			Asst Superintendent	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
P.O. Box 111		605 West Queen Street		Southington	CT	04489
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-628-5593					afiorillo@southingtonwater.org	

Contact Role(s): Legal Contact

Name		Organization			Job Title	
Mr. Douglas R. Arndt		Southington Water Department			Superintendent	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
605 West Queen Street				Southington	CT	06489
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-628-5593					darndt@southingtonwater.org	

Contact Role(s): Administrative Contact

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310031	APPLE VALLEY VILLAGE	C	70	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			41				

Towns Served: SOUTHINGTON

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31				
Total Coliform (3100)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25		Complete		
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				
Lead And Copper (PBCU)		5 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30			
Physical Parameters (PPS)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25		Complete		
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Net Gross Alpha (4000)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25				
	1/1/26 - 12/31/28				
Uranium (4006)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25				
	1/1/26 - 12/31/28				
Combined Radium-226/228 (4010)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25				
	1/1/26 - 12/31/28				
Inorganic Chemicals (IOCS)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/25 - 12/31/27				
Nitrate And Nitrite (NOX)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25		Complete		
	1/1/26 - 12/31/26				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310031	APPLE VALLEY VILLAGE	C	70	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		41					

Towns Served: SOUTHINGTON

Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	6/7/2025
SUBMIT CCR CERTIFICATION FORM	8/9/2025	
CROSS CONNECTION EXEMPTION	3/1/2026	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		4-1	KITCHEN	A	Y			
		AVV WH	WELL HOUSE	A	Y			
		AVV1	UNIT 1	A	Y	N		
		AVV10	UNIT 10	A	Y	3		
		AVV11	UNIT 11	A	Y	N		
		AVV12	UNIT 12	A	Y	N		
		AVV13	UNIT 13	A	Y	N		
		AVV14	UNIT 14	A	Y	N		
		AVV15	UNIT 15	A	Y	N		
		AVV16	UNIT 16	A	Y	3		
		AVV17	UNIT 17	A	Y	N		
		AVV18	UNIT 18	A	Y	3		
		AVV19	UNIT 19	A	Y	N		
		AVV2	UNIT 2	A	Y	N		
		AVV20	UNIT 20	A	Y	3		
		AVV21	UNIT 21	A	Y	N		
		AVV22	UNIT 22	A	Y	N		
		AVV23	UNIT 23	A	Y	N		
		AVV24	UNIT 24	A	Y	N		
		AVV25	UNIT 25	A	Y	N		
		AVV26	UNIT 26	A	Y	1		
		AVV27	UNIT 27	A	Y	N		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310031	APPLE VALLEY VILLAGE	C	70	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		41					

Towns Served: SOUTHINGTON

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		AVV28	UNIT 28	A	Y	N		
		AVV29	UNIT 29	A	Y	1		
		AVV3	UNIT 3	A	Y	N		
		AVV30	UNIT 30	A	Y	N		
		AVV31	UNIT 31	A	Y	N		
		AVV32	UNIT 32	A	Y	3		
		AVV33	UNIT 33	A	Y	N		
		AVV34	UNIT 34	A	Y	3		
		AVV35	UNIT 35	A	Y	N		
		AVV36	UNIT 36	A	Y	3		
		AVV37	UNIT 37	A	Y	N		
		AVV38	UNIT 38	A	Y	1		
		AVV39	UNIT 39	A	Y	3		
		AVV4	UNIT 4	A	Y	N		
		AVV40	UNIT 40	A	Y	3		
		AVV5	UNIT 5	A	Y	N		
		AVV6	UNIT 6	A	Y	3		
		AVV7	UNIT 7	A	Y	N		
		AVV8	UNIT 8	A	Y	N		
		AVV9	UNIT 9	A	Y	3		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
1037	WELL 1	2	WELL 1	A				

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
HELMING, TRAVIS	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2025 9/30/2025

Contact Information

Name			Organization			Job Title		
Mr. Corey Davis			Pyramid Real Estate Group					
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
20 Summer Street						Stamford	CT	06901
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
203-348-8566					corey@pyramidregroup.com			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
CT1310031	APPLE VALLEY VILLAGE	C	70	P	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
		41						
Towns Served: SOUTHINGTON								
Contact Role(s): Legal Contact								
Name			Organization			Job Title		
Mr. Kevin Rohrbacher			Pyramid Ronlestato			Site Manager		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
20 Summer Street						Stamford	CT	06901
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-912-5159					kdrohrbacher@gmail.com			
Contact Role(s): Administrative Contact, Legal Contact								

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule