

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1220007	LIME ROCK PARK, LLC	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
497 LIME ROCK ROAD				12			
Towns Served: SALISBURY							

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	2/1/25 - 2/28/25		Complete	
	3/1/25 - 3/31/25		Complete	
	4/1/25 - 4/30/25		Complete	
	5/1/25 - 5/31/25		Complete	
	6/1/25 - 6/30/25		Complete	
	7/1/25 - 7/31/25			
	8/1/25 - 8/31/25			
	9/1/25 - 9/30/25			
	10/1/25 - 10/31/25			
	11/1/25 - 11/30/25			
	12/1/25 - 12/31/25			

Physical Parameters (PPS)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	2/1/25 - 2/28/25		Complete	
	3/1/25 - 3/31/25		Complete	
	4/1/25 - 4/30/25		Complete	
	5/1/25 - 5/31/25		Complete	
	6/1/25 - 6/30/25		Complete	
	7/1/25 - 7/31/25			
	8/1/25 - 8/31/25			
	9/1/25 - 9/30/25			
	10/1/25 - 10/31/25			
	11/1/25 - 11/30/25			
	12/1/25 - 12/31/25			

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)		1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete	
	1/1/25 - 12/31/25			
	1/1/26 - 12/31/26			

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1220007	LIME ROCK PARK, LLC	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
497 LIME ROCK ROAD				12			
Towns Served: SALISBURY							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00700	ENTRY POINT	3	ENTRY POINT	A				
22091	WELL 1	2	WELL #1	A				
23063	WELL 2	2	WELL #2	A				
ST01	ATMOSPHERIC STORAGE							

Contact Information

Name			Organization			Job Title		
Lime Rock Park Ii LLC								
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
497 Lime Rock Rd						Lakeville	CT	06039
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			

Contact Role(s): **Owner**

Name			Organization			Job Title		
Mr. Skip Barber			Lime Rock Park Ii LLC			Managing Member		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
497 Lime Rock Rd						Lakeville	CT	06039
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-435-5000								

Contact Role(s): **Legal Contact**

Name			Organization			Job Title		
Mr. Robert Jacopino			Lime Rock Park Ii LLC			Facility Operations		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
497 Lime Rock Rd.						Lakeville	CT	06039
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-435-5000	124	860-435-5010		860-671-1629	jocko@limerock.com			

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1220094	O'HARA'S LANDING MARINA	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
254 TWIN LAKES ROAD - SALISBURY				1			
Towns Served: SALISBURY							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		

Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
RESPOND TO SANITARY SURVEY	7/18/2015	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
57194	WELL	2	WELL	A				

Contact Information

Name			Organization			Job Title			
Mr. John M. O'hara, Et Al									
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
1 O'hara Lane						Salisbury		CT	06068
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
203-264-5169									

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
CT1220094	O'HARA'S LANDING MARINA	NC	25	P	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
254 TWIN LAKES ROAD - SALISBURY				1				
Towns Served: SALISBURY								
Contact Role(s): Legal Contact, Owner								
Name			Organization			Job Title		
Mr. David Haab			Brookwood Marine, Inc.			Operator		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
254 Twin Lakes Road						Salisbury	CT	06068
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-824-7583					dave@oharaslanding.com			
Contact Role(s): Administrative Contact, Legal Contact								

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1220134	TWIN LAKES BEACH CLUB	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
TWIN LAKES ROAD				1			
Towns Served: SALISBURY							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)			1 routine (RT) per month
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		

Physical Parameters (PPS)			1 routine (RT) per month
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)			1 routine (RT) per year
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
22098	WELL	2	WELL	A				
63292	TREATMENT PLANT							

Contact Information

Name			Organization			Job Title			
Mr. Jack Mahoney			Twin Lakes Beach Club			President			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
P.O. Box 122						Salisbury		CT	06068
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
201-314-9283					mahoney.jacknyc@me.com				
Contact Role(s): Legal Contact									

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
CT1220134	TWIN LAKES BEACH CLUB	NC	25	P	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
TWIN LAKES ROAD				1				
Towns Served: SALISBURY								
Name			Organization			Job Title		
Ms. Alison Kist			Twin Lakes Beach Club			House Co-Chair		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
268 Twin Lakes Rd						Salisbury	CT	06068
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
347-415-0054					akist99@gmail.com			
Contact Role(s): Administrative Contact								

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1220154	TRINITY EPISCOPAL CHURCH	NC	29	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
484 LIME ROCK ROAD				3			
Towns Served: SALISBURY							

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)		1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	1/1/25 - 3/31/25		Complete	
	4/1/25 - 6/30/25		Complete	
	7/1/25 - 9/30/25			
	10/1/25 - 12/31/25			

Physical Parameters (PPS)		1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	1/1/25 - 3/31/25		Complete	
	4/1/25 - 6/30/25		Complete	
	7/1/25 - 9/30/25			
	10/1/25 - 12/31/25			

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)		1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete	
	1/1/25 - 12/31/25		Complete	
	1/1/26 - 12/31/26			

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
RESPOND TO SANITARY SURVEY	1/3/2009	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
			DOWNSTREAM WITHIN 5 SERVICE CON	A				
			UPSTREAM WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
22760	WELL	2	WELL	A				

Contact Information

Name			Organization			Job Title			
Trinity Episcopal Church									
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
484 Lime Rock Road						Lakeville		CT	06039
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-435-2627									
Contact Role(s):		Owner							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
CT1220154	TRINITY EPISCOPAL CHURCH	NC	29	P	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
484 LIME ROCK ROAD				3				
Towns Served: SALISBURY								
Name			Organization			Job Title		
Mr. Linda Lloyd			Trinity Episcopal Church			Senior Warden		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
484 Lime Rock Rd						Lakeville	CT	06039
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
845-486-4840		845-486-4852		860-435-2627				
Contact Role(s): Legal Contact								
Name			Organization			Job Title		
Rector Heidi Truax			Trinity Episcopal Church-Lr			Rector		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
484 Lime Rock Road						Lakeville	CT	06039
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-435-2627								
Contact Role(s): Administrative Contact								
Please note the following:								
1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.								
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.								
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.								

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1220164	ISOLA BELLA YOUTH CAMP	NC	80	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
410 TWIN LAKES ROAD			6				
Towns Served: SALISBURY							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	6/1/25 - 6/30/25		Complete		
	7/1/25 - 7/31/25				
	8/1/25 - 8/31/25				
	9/1/25 - 9/30/25				

Physical Parameters (PPS)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	6/1/25 - 6/30/25		Complete		
	7/1/25 - 7/31/25				
	8/1/25 - 8/31/25				
	9/1/25 - 9/30/25				

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25		Complete		
	1/1/26 - 12/31/26				

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
CROSS CONNECTION SURVEY REPORT	3/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
			DOWNSTREAM WITHIN 5 SERVICE CON	A				
			UPSTREAM WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
22851	WELL #1	2	WELL #1	A				
55118	TREATMENT PLANT							

Contact Information

Name		Organization			Job Title			
Ms. Jennifer Pizzoferrato		American School For The Deaf			Director Operations			
Mailing Address Line One		Mailing Address Line Two			City		State	Zip Code
Director of Finance And Operations		139 North Main Street			West Hartford		CT	06107
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-570-2372		860-570-2284			jennifer.pizzoferrato@asd-1817.org			
Contact Role(s): Administrative Contact, Legal Contact								

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1220164	ISOLA BELLA YOUTH CAMP	NC	80	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
410 TWIN LAKES ROAD			6				
Towns Served: SALISBURY							

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1221053	SALISBURY SCHOOL - BOAT HOUSE	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
251 CANAAN ROAD - BOAT HOUSE				1			
Towns Served: SALISBURY							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)			1 routine (RT) per quarter
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Physical Parameters (PPS)			1 routine (RT) per quarter
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)			1 routine (RT) per year
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24	4/1-12/31	Complete
	1/1/25 - 12/31/25	4/1-12/31	
	1/1/26 - 12/31/26	4/1-12/31	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A				
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		SSBH001	BOAT HOUSE	A	Y	N		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
56294	WELL	2	WELL	A				

Contact Information

Name			Organization			Job Title			
Mr. Bill Boyer			Salisbury School			Dir Bldgs/Grnds/Safe			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
251 Canaan Rd						Salisbury		CT	06068
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-435-5752		860-435-5750		860-435-5759	wboyer@salisburyschool.org				
Contact Role(s): Administrative Contact									

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
CT1221053	SALISBURY SCHOOL - BOAT HOUSE	NC	25	P	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
251 CANAAN ROAD - BOAT HOUSE				1				
Towns Served: SALISBURY								
Name			Organization			Job Title		
Mr. Vafa Vahid			Salisbury School			Cfo		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
251 Canaan Road						Salisbury	CT	06068
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-435-5709		860-435-5750		860-435-5759	vvahid@salisburyschool.org			
Contact Role(s): Legal Contact								

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule