

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1470011	CTWC - SDC WATER	C	216	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			54				

Towns Served: VOLUNTOWN

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Chlorine Residual (1012)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30		
Total Coliform (3100)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
Disinfectant Byproducts - TTHM & HAA5 (DBP)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SPL STA VALLEY DR (1550)	1/1/24 - 12/31/24	8/10-8/16	Complete
	1/1/25 - 12/31/25	8/10-8/16	
	1/1/26 - 12/31/26	8/10-8/16	
Lead And Copper (PBCU)	5 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/24	6/1-9/30	Complete
	1/1/25 - 12/31/25	6/1-9/30	
	1/1/26 - 12/31/26	6/1-9/30	
Physical Parameters (PPS)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1470011	CTWC - SDC WATER	C	216	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			54				

Towns Served: VOLUNTOWN

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Physical Parameters (PPS)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/27		

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	1 (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25	1/1-12/31	Waiver

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/26 - 12/31/28		

Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1470011	CTWC - SDC WATER	C	216	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			54				

Towns Served: VOLUNTOWN

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 7/1/2003		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Operating Limit Compliance Status:
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
		5/1/2025 - 5/31/2025	
		6/1/2025 - 6/30/2025	

Water System Facility: TREATMENT PLANT (WSFID: 36561)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.40 MG/L	Continuous
Start Date: 11/1/2012		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Operating Limit Compliance Status:
		2/1/2025 - 2/28/2025	Y
		3/1/2025 - 3/31/2025	Y
		4/1/2025 - 4/30/2025	Y
		5/1/2025 - 5/31/2025	Y
		6/1/2025 - 6/30/2025	

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	5/19/2025
CERTIFY LEAD SL NOTIFICATION	7/1/2025	4/3/2025
SUBMIT CCR CERTIFICATION FORM	8/9/2025	
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	
CERTIFY LEAD SL NOTIFICATION	7/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	1550	SPL STA VALLEY DR	A	Y			Y
		1552	LAKESIDE TERRACE SDC	A	Y			
		1580	15 TANGLEWOOD	I				
		1581	22 TANGLEWOOD	A	Y	N		
		1582	30 TANGLEWOOD	A	Y	3		
		1583	45 TANGLEWOOD	A		3		
		1584	39 VALLEY RD	A		1		
		1585	23 VALLEY RD	A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1470011	CTWC - SDC WATER	C	216	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		54					

Towns Served: VOLUNTOWN

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		1586	35 VALLEY	A	Y	N		
		1587	68 VALLEY	A	Y			
		1588	54 VALLEY	A	Y			
		1589	46 VALLEY	A	Y	N		
		1590	38 VALLEY	A	Y	1		
		1591	17 VALLEY	A	Y			
		4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		SDC1592	50 TANGLEWOOD LN	A	Y	1		
		SDC1593	52 TANGLEWOOD LN	A	Y	1		
		SDC1594	11 VALLEY DR	A	Y	1		
		SDC1595	30 VALLEY DR	A	Y	1		
		SDC1596	31 VALLEY DR	A	Y	1		
		SDC1597	2 TANGLEWOOD LN	A	Y	3		
		SDC1598	6 TANGLEWOOD LN	A	Y	3		
		SDC1599	9 TANGLEWOOD LN	A	Y	3		
		SDC1600	11 TANGLEWOOD LN	A	Y	3		
		SDC1601	14 TANGLEWOOD LN	A	Y	3		
		SDC1602	19 TANGLEWOOD LN	A	Y	3		
		SDC1603	20 TANGLEWOOD LN	A	Y	3		
		SDC1604	21 TANGLEWOOD LN	A	Y	3		
		SDC1605	28 TANGLEWOOD LN	A	Y	3		
		SDC1606	34 TANGLEWOOD LN	A	Y	3		
		SDC1607	35 TANGLEWOOD LN	A	Y	3		
		SDC1608	38 TANGLEWOOD LN	A	Y	3		
		SDC1609	39 TANGLEWOOD LN	A	Y	3		
		SDC1610	40 TANGLEWOOD LN	A	Y	3		
		SDC1611	41 TANGLEWOOD LN	A	Y	3		
		SDC1612	44 TANGLEWOOD LN	A	Y	3		
		SDC1613	46 TANGLEWOOD LN	A	Y	3		
		SDC1614	47 TANGLEWOOD LN	A	Y	3		
		SDC1615	27 VALLEY DR	A	Y	N		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
36561	TREATMENT PLANT							
50126	ATMOSPHERIC TANK							
52086	PUMP STATION							
536	WELL #2	2	WELL #2	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1470011	CTWC - SDC WATER	C	216	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		54					

Towns Served: VOLUNTOWN

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
537	WELL #1	2	WELL #1	A				

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
KEARNEY, THOMAS	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2026
		WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2026

Water System Facility: **TREATMENT PLANT (WSF ID: 36561)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
WILCOX, MELISSA	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2025
SWEET, BRYAN S	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2026

Contact Information

Name		Organization			Job Title	
Mr. Craig J. Patla		Connecticut Water Company			Vp, Service Delivery	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
93 West Main Street				Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-664-6140				800-391-1924	craig.patla@ctwater.com	

Contact Role(s): **Legal Contact, Owner**

Name		Organization			Job Title	
Mr. Paul C. Lowry		Connecticut Water Company			Manager	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
93 W Main Street				Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-292-2809		860-654-1903		800-208-5700	ctwcdphadmin@ctwater.com	

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1479021	VOLUNTOWN HOUSING AUTHORITY	C	42	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
239 MAIN STREET			4				
Towns Served: VOLUNTOWN							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Asbestos (1094)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points		1/1/20 - 12/31/28			
Total Coliform (3100)		3 repeat (RP) per period			
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points		1/7/25 - 1/12/25		Complete	
Total Coliform (3100)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points		2/1/25 - 2/28/25		Complete	
		3/1/25 - 3/31/25		Complete	
		4/1/25 - 4/30/25		Complete	
		5/1/25 - 5/31/25		Complete	
		6/1/25 - 6/30/25		Complete	
		7/1/25 - 7/31/25		Complete	
		8/1/25 - 8/31/25		Complete	
		9/1/25 - 9/30/25		Complete	
		10/1/25 - 10/31/25		Complete	
		11/1/25 - 11/30/25		Complete	
		12/1/25 - 12/31/25		Complete	
Lead And Copper (PBCU)		5 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points		1/1/24 - 12/31/24	6/1-9/30	Complete	
		1/1/25 - 12/31/25	6/1-9/30		
		1/1/26 - 12/31/26	6/1-9/30		
Physical Parameters (PPS)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points		2/1/25 - 2/28/25		Complete	
		3/1/25 - 3/31/25		Complete	
		4/1/25 - 4/30/25		Complete	
		5/1/25 - 5/31/25		Complete	
		6/1/25 - 6/30/25		Complete	
		7/1/25 - 7/31/25		Complete	
		8/1/25 - 8/31/25		Complete	
		9/1/25 - 9/30/25		Complete	
		10/1/25 - 10/31/25		Complete	
		11/1/25 - 11/30/25		Complete	
		12/1/25 - 12/31/25		Complete	

Water System Facility: ENTRY POINT (WSF ID: 00700)

Inorganic Chemicals (IOCS)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1479021	VOLUNTOWN HOUSING AUTHORITY	C	42	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
239 MAIN STREET			4				
Towns Served: VOLUNTOWN							

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Inorganic Chemicals (IOCS)		1 routine (RT) per three years			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status		
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete		
	1/1/26 - 12/31/28				
Nitrate And Nitrite (NOX)		1 routine (RT) per year			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status		
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25		Complete		
	1/1/26 - 12/31/26				
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per nine years			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status		
ENTRY POINT (3)	1/1/23 - 12/31/31				
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status		
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete		
	1/1/26 - 12/31/28				
Organic Chemicals (VOCS)		1 routine (RT) per year			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status		
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25		Complete		
	1/1/26 - 12/31/26				

Water System Facility: WELL 1 (WSF ID: 54751)

E. Coli (3014)		1 triggered (TG) per period		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
WELL 1 (2)	1/6/25 - 1/12/25		Complete	

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT FISCAL AND ASSET MANAGEMENT CERT	1/1/2021	
RESPOND TO SANITARY SURVEY	11/9/2023	
CROSS CONNECTION EXEMPTION	3/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION	A				
		B1-1B	APT 1 BATH	A	Y	N		
		B1-1K	APT 1 KITCHEN	A	Y	N		
		B1-2B	APT 2 BATH	A	Y	N		
		B1-2K	APT 2 KITCHEN	A	Y	N		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1479021	VOLUNTOWN HOUSING AUTHORITY	C	42	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
239 MAIN STREET		4					

Towns Served: VOLUNTOWN

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		B1-3B	APT 3 BATH	A	Y	N		
		B1-3K	APT 2 KITCHEN	A	Y	N		
		B1-4B	APT 4 BATH	A	Y	N		
		B1-4K	APT 4 KITCHEN	A	Y	N		
		B2-10B	APT 10 BATH	A	Y	N		
		B2-10K	APT 10 KITCHEN	A	Y	N		
		B2-11B	APT 11 BATH	A	Y	N		
		B2-11K	APT 11 KITCHEN	A	Y	N		
		B2-12B	APT 12 BATH	A	Y	N		
		B2-12K	APT 12 KITCHEN	A	Y	N		
		B2-5B	APT 5 BATH	A	Y	N		
		B2-5K	APT 5 KITCHEN	A	Y	N		
		B2-6B	APT 6 BATH	A	Y	N		
		B2-6K	APT 6 KITCHEN	A	Y	N		
		B2-7B	APT 7 BATH	A	Y	N		
		B2-7K	APT 7 KITCHEN	A	Y	N		
		B2-8B	APT 8 BATH	A	Y	N		
		B2-8K	APT 8 KITCHEN	A	Y	N		
		B2-9B	APT 9 BATH	A	Y	N		
		B2-9K	APT 9 KITCHEN	A	Y	N		
		B3-13B	APT 13 BATH	A	Y	N		
		B3-13K	APT 13 KITCHEN	A	Y	N		
		B3-14B	APT 14 BATH	A	Y	N		
		B3-14K	APT 14 KITCHEN	A	Y	N		
		B3-15B	APT 15 BATH	A	Y	N		
		B3-15K	APT 15 KITCHEN	A	Y	N		
		B3-16B	APT 16 BATH	A	Y	N		
		B3-16K	APT 16 KITCHEN	A	Y	N		
		B3-17B	APT 17 BATH	A	Y	N		
		B3-17K	APT 17 KITCHEN	A	Y	N		
		B3-18B	APT 18 BATH	A	Y	N		
		B3-18K	APT 18 KITCHEN	A	Y	N		
		B3-19B	APT 19 BATH	A	Y	N		
		B3-19K	APT 19 KITCHEN	A	Y	N		
		B3-20B	APT 20 BATH	A	Y	N		
		B3-20K	APT 20 KITCHEN	A	Y	N		
		B4-1	UTILITY ROOM	A	Y	N		
		B4-2	COM BUILDING KITCHEN	A	Y	N		
		B4-3	COM BUILDING MNS SIN	A	Y	N		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1479021	VOLUNTOWN HOUSING AUTHORITY	C	42	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
239 MAIN STREET			4				
Towns Served: VOLUNTOWN							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		B4-4	COM BUILDING WNS SIN	A	Y	N		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
54751	WELL 1	2	WELL 1	A				
55569	TREATMENT PLANT							

Certified Operator Information

Water System Facility: TREATMENT PLANT (WSF ID: 55569)			
Facility Classification: CLASS 1 TREATMENT PLANT			
Operator Name	Operator Type	Certification(s)	Certification Expiration
LAPORTE, SCOTT	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2028

Contact Information

Name		Organization			Job Title			
Ms. Wendy Vachon		Voluntown Housing Authority			Executive Director			
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
239 Main St						Voluntown	CT	06384
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-376-5169				860-376-5169	vha147@sbcglobal.net			
Contact Role(s): Administrative Contact, Legal Contact, Owner								
Name		Organization			Job Title			
Voluntown Housing Authority								
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
Emergency Contact						Emergency Contact	CT	06000
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-376-5169								
Contact Role(s): Owner								

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule