

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1600503	PHELPS CROSSING COMMERCIAL	NTNC	50	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
PHELPS WAY, ROUTE 32-74			1				
Towns Served: WILLINGTON							

## Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28				
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25		Complete		
	7/1/25 - 9/30/25		Complete		
	10/1/25 - 12/31/25				
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30			
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25		Complete		
	7/1/25 - 9/30/25		Complete		
	10/1/25 - 12/31/25				

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/26				
	1/1/27 - 12/31/29				
<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25		Complete		
	1/1/26 - 12/31/26				
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25				
	1/1/26 - 12/31/28				
<b>Organic Chemicals (VOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/26				
	1/1/27 - 12/31/29				

## Monthly Water System Facility (WSF) Level Monitoring Requirements

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1600503	PHELPS CROSSING COMMERCIAL	NTNC	50	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
PHELPS WAY, ROUTE 32-74			1				

Towns Served: WILLINGTON

### Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7 PH	4
<b>Start Date:</b> 1/1/2002	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
CROSS CONNECTION SURVEY REPORT	3/1/2026	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		PXG-CC	CURVES FOR WOMEN	A	Y	N	Y	Y
		PXG-CCS	CREATIVE CONCEPTS	A	Y	N	Y	Y
		PXG-DGR	DAILY GRIND CAFE	A	Y	N	Y	Y
		PXG-DWD	D WOOD DENTIST	A	Y	1	Y	Y
		PXG-EE	ELEGANT EDGE	A	Y	N	Y	Y
		PXG-ENSR	ENSR INTERNATIONAL	A	Y	N	Y	Y
		PXG-FHC	FAMILY HEALTH CARE	I	Y	N	Y	Y
		PXG-HWS	HELENS WINE & SPIRIT	A	Y	N	Y	Y
		PXG-KB	KEY BANK	A		2		Y
		PXG-LD	LEAPS & DREAMS	A	Y	N	Y	Y
		PXG-MM	MOON MONOCLE	A	Y	N	Y	Y
		PXG-NAB	NEW ALLIANCE BANK	A	Y	N	Y	Y
		PXG-USPS	US POSTAL SERV	A		N	Y	Y
		PXG-VAC1	VACANT 1	A		N	Y	Y
		PXG-VAC2	VACANT 2	A		N	Y	Y
		PXG-VAC3	VACANT 3	A		N	Y	Y
		PXG-VAC4	VACANT 4	A		N	Y	Y
		PXG-WC	WILLINGTON CONVENIEN	A	Y	N	Y	Y
PXG-WP2	WILLI PIZZA 2	A	Y	N	Y	Y		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1600503</b>	<b>PHELPS CROSSING COMMERCIAL</b>	NTNC	50	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
PHELPS WAY, ROUTE 32-74			1				
Towns Served: WILLINGTON							

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
10678	WELL	2	WELL	A				
1553	CALCITE FILTER							

## Certified Operator Information

Water System Facility: **CALCITE FILTER (WSF ID: 1553)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
NIGRO, JR., VICTOR N.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2026
NIGRO, SCOTT A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026

## Contact Information

Name		Organization			Job Title			
<b>Mr. Catharine Marak</b>		Dtv Realty of Willington LLC			Partner			
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
770 Sullivan Avenue						South Windsor	CT	06074
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-289-7821				860-289-7821	lotsandmoreswww@gmail.com			

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1600513</b>	<b>TA TRAVEL PLAZA</b>	NTNC	130	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
327 RUBY ROAD			1				
Towns Served: WILLINGTON							

### Monitoring Requirements

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Chlorine Residual (1012)</b>		<b>2 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25		Complete		
<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28				
<b>Total Haloacetic Acids (2456)</b>		<b>2 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
HOTEL BREAK ROOM (HBR)	1/1/24 - 12/31/24	9/1-9/30	Complete		
	1/1/25 - 12/31/25	9/1-9/30			
	1/1/26 - 12/31/26	9/1-9/30			
TA KITCHEN (TAK)	1/1/24 - 12/31/24	9/1-9/30	Complete		
	1/1/25 - 12/31/25	9/1-9/30			
	1/1/26 - 12/31/26	9/1-9/30			
<b>Total Trihalomethanes (2950)</b>		<b>2 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
HOTEL ROOM 322 (H322)	1/1/24 - 12/31/24	9/1-9/30	Complete		
	1/1/25 - 12/31/25	9/1-9/30			
	1/1/26 - 12/31/26	9/1-9/30			
BURGER KING (TABK)	1/1/24 - 12/31/24	9/1-9/30	Complete		
	1/1/25 - 12/31/25	9/1-9/30			
	1/1/26 - 12/31/26	9/1-9/30			
<b>Total Coliform (3100)</b>		<b>2 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25		Complete		
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				
<b>Lead And Copper (PBCU)</b>		<b>10 routine (RT) per six months</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/25 - 6/30/25		Complete		
	7/1/25 - 12/31/25				
<b>Physical Parameters (PPS)</b>		<b>2 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25		Complete		
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

**Water System Facility: ENTRY POINT - DUNKIN DONUTS (WSF ID: 00700)**

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1600513	TA TRAVEL PLAZA	NTNC	130	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
327 RUBY ROAD			1				
Towns Served: WILLINGTON							

### Monitoring Requirements

**Water System Facility:** ENTRY POINT - DUNKIN DONUTS (WSF ID: 00700)

<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT - DUNKIN (3)	1/1/25 - 12/31/27				
<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT - DUNKIN (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25		Complete		
	1/1/26 - 12/31/26				
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>		<b>1 (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT - DUNKIN (3)	1/1/23 - 12/31/25	1/1-12/31	Waiver		
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT - DUNKIN (3)	1/1/26 - 12/31/28				
<b>Organic Chemicals (VOCS)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT - DUNKIN (3)	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25		Complete		
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

**Water System Facility:** ENTRY POINT - SLEEP INN (WSF ID: 00701)

<b>Nickel (1036)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT - SLEEP (3)	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25		Complete		
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				
<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT - SLEEP (3)	1/1/25 - 12/31/27				
<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT - SLEEP (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25		Complete		
	1/1/26 - 12/31/26				
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>		<b>1 (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT - SLEEP (3)	1/1/23 - 12/31/25	1/1-12/31	Waiver		
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1600513</b>	<b>TA TRAVEL PLAZA</b>	NTNC	130	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
327 RUBY ROAD			1				
Towns Served: WILLINGTON							

### Monitoring Requirements

**Water System Facility: ENTRY POINT - SLEEP INN (WSF ID: 00701)**

**Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS) 1 routine (RT) per three years**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT - SLEEP (3)	1/1/26 - 12/31/28		

**Organic Chemicals (VOCS) 1 routine (RT) per quarter**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT - SLEEP (3)	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

**Water System Facility: WELL #1 (WSF ID: 10679)**

**E. Coli (3014) 1 routine (RT) per quarter**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL #1 (2)	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

**Water System Facility: WELL #5 (WSF ID: 61434)**

**E. Coli (3014) 1 routine (RT) per quarter**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL #5 (2)	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

**Water System Facility: WELL #6 (WSF ID: 61436)**

**E. Coli (3014) 1 routine (RT) per quarter**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL #6 (2)	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

### Monthly Water System Facility (WSF) Level Monitoring Requirements

**Water System Facility: ENTRY POINT - DUNKIN DONUTS (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 1/1/2002	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1600513</b>	<b>TA TRAVEL PLAZA</b>	NTNC	130	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
327 RUBY ROAD			1				

Towns Served: WILLINGTON

### Water System Facility: ENTRY POINT - DUNKIN DONUTS (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 1/1/2002	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		

### Water System Facility: ENTRY POINT - SLEEP INN (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 1/1/2004	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2025	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DDHS	DD HAND SINK	A		1		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		H322	HOTEL ROOM 322	A		1		Y
		HBR	HOTEL BREAK ROOM	A		1		Y
		RSRR	REPAIR SHOP RESTRM	A		1		
		TABK	BURGER KING	A		1		Y
		TABKK	BURGER KING 2	A	Y	1		
		TAHS	TA KITCHEN HAND SINK	A		1		
		TAK	TA KITCHEN	A		1		Y
		TARSS	TA REST SLOP SINK	A		1		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		WSS	WAITRESS STATION SIN	A		1		
00700	ENTRY POINT - DUNKIN DONUTS	3	ENTRY POINT - DUNKIN	A				
00701	ENTRY POINT - SLEEP INN	3	ENTRY POINT - SLEEP	A				
1003	TA TRAVEL PLAZA WTP - SLEEP IN							
10679	WELL #1	2	WELL #1	A				
46570	ATMOSPHERIC STORAGE							

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1600513</b>	<b>TA TRAVEL PLAZA</b>	NTNC	130	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
327 RUBY ROAD			1				
Towns Served: WILLINGTON							

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
46573	HYRDROPNEUMATIC TANK							
53067	TA TRAVEL PLAZA WTP - DUNKIN DONUTS							
53547	BOOSTER PUMP STATION							
61434	WELL #5	2	WELL #5	A				
61436	WELL #6	2	WELL #6	A				

## Certified Operator Information

**Water System Facility: TA TRAVEL PLAZA WTP - SLEEP IN (WSF ID: 1003)**

**Facility Classification:** CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAFRAMBOISE, ERIC	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2026
		WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2026
NAPIERATA, KYLE	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2027
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2027
LAFRAMBOISE, PAUL F.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2027
STARK, TYLER	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2028
		WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2028

**Water System Facility: TA TRAVEL PLAZA WTP - DUNKIN DONUTS (WSF ID: 53067)**

**Facility Classification:** CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAFRAMBOISE, ERIC	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2026
		WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2026
NAPIERATA, KYLE	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2027
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2027
LAFRAMBOISE, PAUL F.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2027
STARK, TYLER	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2028
		WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2028

## Contact Information

Name		Organization			Job Title			
Ms. Kelly Gelske		TA Operating Corp						
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
24601 Center Ridge Road						Westlake	OH	44145
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
440-808-4431		440-808-3307		888-578-3693	GELSKE.KELLY@TATRavelCENTERS.COM			
<b>Contact Role(s): Administrative Contact, Legal Contact, Owner</b>								

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source	
<b>CT1600513</b>	<b>TA TRAVEL PLAZA</b>	NTNC	130	P	GW	
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
327 RUBY ROAD		1				
Towns Served: WILLINGTON						

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1600523</b>	<b>FED EX GROUND</b>	NTNC	200	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
350 RUBY ROAD			1				
Towns Served: WILLINGTON							

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28				
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25		Complete		
	7/1/25 - 9/30/25		Complete		
	10/1/25 - 12/31/25				
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/25	6/1-9/30			
	1/1/26 - 12/31/28	6/1-9/30			
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25		Complete		
	7/1/25 - 9/30/25		Complete		
	10/1/25 - 12/31/25				
Water System Facility: <b>ENTRY POINT (WSF ID: 00700)</b>					
<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete		
	1/1/26 - 12/31/28				
<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25		Complete		
	1/1/26 - 12/31/26				
<b>Pesticides, Herbicides and PCBs-Phase II (SOC2)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete		
	1/1/26 - 12/31/28				
<b>Pesticides, Herbicides and PCBs-Phase V (SOC5)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete		
	1/1/26 - 12/31/28				
<b>Organic Chemicals (VOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1600523</b>	<b>FED EX GROUND</b>	NTNC	200	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
350 RUBY ROAD			1				
Towns Served: WILLINGTON							

## Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per three years</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>
	<i>Collection Period</i>
	<i>Compliance Status</i>
	1/1/26 - 12/31/28

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	4
<b>Start Date:</b> 9/1/2009	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2026	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		LLC001	LOWER LEVEL COOLER	P	Y	1		
		LLC002	LOWER LEVEL COOLER	P	Y	1		
		LLC003	LOWER LEVEL COOLER	P	Y	1		
		LLC004	LOWER LEVEL COOLER	P	Y	1		
		LLC005	LOWER LEVEL COOLER	P	Y	1		
		LLC006	LOWER LEVEL COOLER	P	Y	1		
		LLC007	LOWER LEVEL COOLER	P	Y	1		
		LLC008	LOWER LEVEL COOLER	P	Y	1		
		LLC009	LOWER LEVEL COOLER	P	Y	1		
		LLC010	LOWER LEVEL COOLER	P	Y	1		
		LLS001	LOWER LEVEL SINK	P	Y	1		
		LLS002	LOWER LEVEL SINK	P	Y	1		
		LLS003	LOWER LEVEL SINK	P	Y	1		
		LLS004	LOWER LEVEL SINK	P	Y	1		
		LLS005	LOWER LEVEL SINK	P	Y	1		
		LLS006	LOWER LEVEL SINK	P	Y	1		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1600523</b>	<b>FED EX GROUND</b>	NTNC	200	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
350 RUBY ROAD			1				
Towns Served: WILLINGTON							

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		LLS007	LOWER LEVEL SINK	P	Y	1		
		LLS008	LOWER LEVEL SINK	P	Y	1		
		LLS009	LOWER LEVEL SINK	P	Y	1		
		LLS010	LOWER LEVEL SINK	P	Y	1		
		ULC001	UPPER LEVEL COOLER	P	Y	1		
		ULC002	UPPER LEVEL COOLER	P	Y	1		
		ULS001	UPPER LEVEL SINK	P	Y	1		
		ULS002	UPPER LEVEL SINK	P	Y	1		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10680	WELL #2	2	WELL #2	A				
10681	WELL #1	2	WELL #1	A				
55661	ATMOSPHERIC TANK							
55663	HYDROPNEUMATIC TANK							
56371	TREATMENT PLANT							

### Certified Operator Information

<b>Water System Facility: TREATMENT PLANT (WSF ID: 56371)</b>			
<b>Facility Classification:</b> CLASS 1 TREATMENT PLANT			
Operator Name	Operator Type	Certification(s)	Certification Expiration
NIGRO, JR., VICTOR N.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2026
NIGRO, SCOTT A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026
NIGRO, DAVID	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2028

### Contact Information

Name		Organization			Job Title		
Mr. William Moreau		Fed Ex Ground			Facility Manager		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
Fed Ex Ground Facility Manager		350 Ruby Road			Willington	CT	06279
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-684-8934		860-684-1488			william.moreau@fedex.com		
Contact Role(s): <b>Administrative Contact</b>							

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
<b>CT1600523</b>	<b>FED EX GROUND</b>	NTNC	200	P	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
350 RUBY ROAD			1					
Towns Served: WILLINGTON								
Name			Organization			Job Title		
<b>Mr. Paul Stoklosa</b>			Fed Ed Ground					
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
1000 Fed Ex Rd						Moon Township	PA	15108
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
412-859-2384					paul.stoklosa@fedex.com			

Contact Role(s): **Legal Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1609133</b>	<b>KIDS KINGDOM DAYCARE CENTER</b>	NTNC	118	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
330 RIVER RD				1			
Towns Served: WILLINGTON							

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28				
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25		Complete		
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/25	6/1-9/30	Complete		
	1/1/25 - 12/31/27	6/1-9/30			
	1/1/28 - 12/31/30	6/1-9/30			
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25		Complete		
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				
Water System Facility: <b>ENTRY POINT (WSF ID: 00700)</b>					
<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25				
	1/1/26 - 12/31/28				
<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25		Complete		
	1/1/26 - 12/31/26				
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25				
	1/1/26 - 12/31/28				
<b>Organic Chemicals (VOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete		
	1/1/26 - 12/31/28				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1609133</b>	<b>KIDS KINGDOM DAYCARE CENTER</b>	NTNC	118	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
330 RIVER RD				1			
Towns Served: WILLINGTON							

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
CROSS CONNECTION EXEMPTION	3/1/2029	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y	N		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		MSP0001	SINK- AGE 1-2	A	Y	N		
		MSP0002	SINK- AGE 2-3	A	Y	N		
		MSP0003	SINK- INFANT	A	Y	N		
		MSP0004	SINK- HALL BATHROOM	A	Y	N		
		MSP0005	SINK-GROSS MOTOR RM	A	Y	N		
		MSP0006	L BR SINK- AGE 3-5	A	Y	N		
		MSP0007	SINK- BREAK RM	A	Y	N		
		MSP0008	SINK- SCHOOL AGE	A	Y	N		
		MSP0009	SINK- AGE 3-5	A	Y	N		
		MSP0010	BATH SINK- AGE 2-3	A	Y	N		
		MSP0011	BATH SINK GR MOTOR	A	Y	N		
		MSP0012	BATH SINK AFTER SCH	A	Y	N		
		MSP0013	KITCH SINK AFTER SCH	A	Y	N		
		MSP0014	SINK AGE 4	A	Y	N		
		MSP0015	WINK AGE 1	A	Y	N		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
53141	WELL 1	2	WELL 1	A				
53144	WELL 2	2	WELL 2	A				

## Certified Operator Information

Water System Facility: <b>DISTRIBUTION SYSTEM (WSF ID: 00600)</b>			
Facility Classification: SMALL WATER SYSTEM			
<b>Operator Name</b>	<b>Operator Type</b>	<b>Certification(s)</b>	<b>Certification Expiration</b>
STAVENS, JOEL	CHIEF OPERATOR	SMALL WATER SYSTEM OPERATOR	6/30/2026

## Contact Information

Name		Organization			Job Title		
<b>Mr. Daniel R. Cote</b>		D & D Property Holdings LLC					
Mailing Address Line One			Mailing Address Line Two		City	State	Zip Code
46 Timber Lane					Wilmington	CT	06279
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-333-8177		860-438-5464			cote@dep.state.ct.us		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1609133</b>	<b>KIDS KINGDOM DAYCARE CENTER</b>	NTNC	118	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
330 RIVER RD				1			
Towns Served: WILLINGTON							
860-933-0177		860-429-5464		scote@charter.net			
Contact Role(s): <b>Administrative Contact, Legal Contact, Owner</b>							

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1609203	LOVE'S TRAVEL STOP & COUNTRY STORE	NTNC	130	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
3 POLSTER ROAD						1	
Towns Served: WILLINGTON							

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31				
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25		Complete		
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				
<b>Lead And Copper (PBCU)</b>		<b>10 routine (RT) per six months</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/25 - 6/30/25		Complete		
	7/1/25 - 12/31/25				
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25		Complete		
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				
Water System Facility: <b>ENTRY POINT (WSF ID: 00700)</b>					
<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25				
	1/1/26 - 12/31/28				
<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25				
	1/1/26 - 12/31/26				
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25		Complete		
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				
<b>Organic Chemicals (VOCS)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25		Complete		
	7/1/25 - 9/30/25				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1609203	LOVE'S TRAVEL STOP & COUNTRY STORE	NTNC	130	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
3 POLSTER ROAD						1	
Towns Served: WILLINGTON							

## Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>Organic Chemicals (VOCS)</b>				<b>1 routine (RT) per quarter</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>		<i>Compliance Status</i>
	10/1/25 - 12/31/25			

Water System Facility: **WELL 1 (SOUTH) (WSF ID: 62568)**

<b>E. Coli (3014)</b>				<b>1 routine (RT) per quarter</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>		<i>Compliance Status</i>
WELL 1 (SOUTH) (2)	1/1/25 - 3/31/25			Complete
	4/1/25 - 6/30/25			Complete
	7/1/25 - 9/30/25			
	10/1/25 - 12/31/25			

Water System Facility: **WELL 2 (NORTH) (WSF ID: 62570)**

<b>E. Coli (3014)</b>				<b>1 routine (RT) per quarter</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>		<i>Compliance Status</i>
WELL 2 (NORTH) (2)	1/1/25 - 3/31/25			Complete
	4/1/25 - 6/30/25			Complete
	7/1/25 - 9/30/25			
	10/1/25 - 12/31/25			

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT (WSFID: 00700)**

<b>Analyte</b>	<b>Monitoring Requirement (Summary Type)</b>	<b>Operating Limit</b>	<b>Samples Req/Month</b>
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 10/1/2022	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		

<b>Analyte</b>	<b>Monitoring Requirement (Summary Type)</b>	<b>Operating Limit</b>	<b>Samples Req/Month</b>
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 1.0 MG/L	2
<b>Start Date:</b> 12/1/2022	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1609203</b>	<b>LOVE'S TRAVEL STOP &amp; COUNTRY STORE</b>	NTNC	130	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
3 POLSTER ROAD						1	
Towns Served: WILLINGTON							

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2024	
CROSS CONNECTION SURVEY REPORT	3/1/2025	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 4 SERVICE CON	A	Y			
		LOVES1	SUBWAY PREP SINK	A	Y	N		
		LOVES10	SUBWAY HAND SINK	A	Y	N		
		LOVES2	MEN'S RM MANUAL SINK	A	Y	N		
		LOVES3	DELI DEPT HANDWASH	A	Y	N		
		LOVES4	DELI DEPT PREP SINK	A	Y	N		
		LOVES5	COFFEE AREA SINK	A	Y	N		
		LOVES6	GF FRONT HAND SINK	A	Y	N		
		LOVES7	GF DISHWASH SINK	A	Y	N		
		LOVES8	GF PREP SINK	A	Y	N		
		LOVES9	GF HAND SINK	A	Y	N		
		UPSTREAM	WITHIN 4 SERVICE CON	A	Y			
00700	ENTRY POINT	3	ENTRY POINT	A				
62568	WELL 1 (SOUTH)	2	WELL 1 (SOUTH)	A				
62570	WELL 2 (NORTH)	2	WELL 2 (NORTH)	A				
62572	LOVE'S TREATMENT PLANT							
62574	ATM STORAGE							
62576	LOVE'S PUMP STATION							

## Certified Operator Information

<b>Water System Facility: LOVE'S TREATMENT PLANT (WSF ID: 62572)</b>			
<b>Facility Classification: CLASS 2 TREATMENT PLANT</b>			
Operator Name	Operator Type	Certification(s)	Certification Expiration
LAFRAMBOISE, PAUL F.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2027
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2027
NAPIERATA, KYLE	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2027
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2027
ENGLE, ROGER D.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2026
LAFRAMBOISE, ERIC	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2026
STARK, TYLER	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2028
		WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2028

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1609203	LOVE'S TRAVEL STOP & COUNTRY STORE	NTNC	130	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
3 POLSTER ROAD						1	
Towns Served: WILLINGTON							

## Contact Information

Name			Organization			Job Title			
Mr. Rick Shuffield						Director of Real Est			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
10601 N Pennsylvania Ave						Oklahoma City		OK	73120
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
405-302-6646					Rick.shuffield@loves.com				
Contact Role(s): <b>Administrative Contact, Legal Contact, Owner</b>									

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**